



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2017 Edition

Reference: 725.144(B)

TIA 17-11

(SC 17-12-8 / TIA Log #1300)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70[®], *National Electrical Code*[®], 2017 edition. The TIA was processed by the National Electrical Code Panel 3 and the NEC Correlating Committee, and was issued by the Standards Council on December 6, 2017, with an effective date of December 26, 2017.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise 725.144(B) to read as follows:*

725.144(B) Use of Class 2-LP or Class 3-LP Cables to Transmit Power and Data. Types CL3P-LP, CL2P-LP, CL3R-LP, CL2R-LP, CL3-LP, or CL2-LP shall be permitted to supply power to equipment at a current level up to the marked ampere limit located immediately following the suffix LP and shall be permitted to transmit data to the equipment. For ambient temperatures above 30°C (86°F), the correction factors of 310.15(B)(2) shall apply. The Class 2-LP and Class 3-LP cables shall comply with the following, as applicable: ...

Issue Date: December 6, 2017

Effective Date: December 26, 2017

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2017 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION