



Standard Test Method for Free Water, Particulate and Other Contamination in Aviation Fuels (Visual Inspection Procedures)¹

This standard is issued under the fixed designation D6986; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

Fuel quality is paramount in aviation fuels because of their critical application. Many successive types of inspections are conducted to ensure quality protection. Rapid, visual inspections carried out at various locations in the fuel supply system are a critical part of the inspection program. Experience has shown that subjective evaluations such as described by this test method form an effective field alert system that is backed by other, more quantitative tests.

The present test method duplicates much of Test Method D4176, a test method applicable to all distillate fuels. However, the present test method also includes field methods applicable especially to aviation fuels, and is therefore published as a separate test method.

1. Scope

1.1 This test method covers two procedures for establishing the presence of suspended free water, solid particulate, and other contaminants in aviation gasoline and aviation turbine fuels.

1.1.1 Both procedures are intended primarily for use as field tests with the fuel at handling temperature.

1.1.2 Procedure A uses transparent sample containers; Procedure B uses opaque containers.

1.2 Both procedures are rapid methods for contamination detection and include ratings of haze appearance and particulate presence.

1.3 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information only.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee D02.J0 on Aviation Fuels.

Current edition approved May 1, 2020. Published June 2020. Originally published in 2003. Last previous edition approved in 2016 as D6986 – 03 (2016). DOI: 10.1520/D6986-03R20.

2. Referenced Documents

2.1 ASTM Standards:²

D2276 Test Method for Particulate Contaminant in Aviation Fuel by Line Sampling

D3240 Test Method for Undissolved Water In Aviation Turbine Fuels

D4057 Practice for Manual Sampling of Petroleum and Petroleum Products

D4176 Test Method for Free Water and Particulate Contamination in Distillate Fuels (Visual Inspection Procedures)

D5452 Test Method for Particulate Contamination in Aviation Fuels by Laboratory Filtration

2.2 ASTM Adjuncts:

ADJD417601 Distillate Fuel Bar Chart³

ADJD417602 Distillate Fuel Haze Rating Standard⁴

3. Terminology

3.1 Definitions of Terms Specific to This Standard:

3.1.1 *aviation fuels, n*—as used in this standard, the term includes both aviation gasoline and aviation turbine fuels.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from ASTM International Headquarters. Order Adjunct No. ADJD417601.

⁴ Available from ASTM International Headquarters. Order Adjunct No. ADJD417602.

3.1.2 *clear and bright, adj*—a condition in which the fuel contains no visible water drops or particulates and is free of haze or cloudiness.

3.1.3 *free water, n*—water in excess to that soluble in the fuel at the temperature of the test and may appear in the fuel as a haze, cloudiness, droplets, or water layer.

3.1.4 *solid particulates, n*—small solid or semi-solid particles, sometimes referred to as silt or sediment, present in a fuel as the result of contamination by airborne dusts, corrosion by-products, or wear products.

4. Summary of Test Method

4.1 The test method describes two types of sampling containers for evaluating the appearance of aviation fuel samples. Procedure A covers transparent sample containers, including the open jar and the closed circuit sampler, while Procedure B uses opaque containers such as the white bucket.

4.2 In the open jar procedure, a minimum of 750 mL (24 oz) of fuel is placed into a clear one litre (1 qt) container and examined visually. The jar is then closed and the sample is swirled and examined for visual sediment and water at the bottom of the vortex. Additionally, fuel clarity may be rated by placing a standard bar chart behind the sample and comparing its visual appearance with the standard haze rating photographs. The presence or absence of free water and of particulates is reported.

4.3 In the closed circuit sampler procedure, approximately 3500 mL (0.9 U.S. gal) of fuel is placed into the sampler and is examined for clarity and for visual sediment or water droplets on the bottom of the sampler. Additionally, fuel clarity may be rated by placing a standard bar chart behind the sample and comparing its visual appearance with the standard haze rating photographs. The presence or absence of free water and of particulates is reported.

4.4 In the white bucket procedure fuel to a depth of approximately 15 cm (6 in.) is collected in a white porcelain coated or stainless steel bucket. The sample is examined for solids or sediment, or both, on the bottom of the bucket. Sample clarity can be checked by the appearance of a small, shiny coin on the bucket's bottom. If the fuel is dry, the raised letters on the coin should be easily readable. The amount of sediment can be described by a letter category using a rating guide.

4.5 In both procedures, the sample is inspected for color or other unusual appearance.

4.6 Field inspection procedures are performed immediately after sampling at fuel handling temperature conditions.

5. Significance and Use

5.1 The two procedures in the test method provide rapid methods for field detection of free water and solid contaminants, or any other visually apparent contamination. Uncertain or marginal results by either of these methods would normally result in the performance of methods such as [D2276](#), [D5452](#), or [D3240](#) for quantitative determination of contaminants.

5.1.1 Particulate determination in appearance tests is sensitive to sampling procedures. The presence of a small number of particles may indicate, for example, that the sample line was not flushed to provide a representative sample. The persistent presence of even a small number of particles, however, may be cause for further investigation depending on the situation.

5.2 Experience has shown that an experienced tester using a clear bottle can detect as little as 40 ppm of free, suspended water in the fuel. Thus, a fuel rated as *clear and bright* can still fail lower limits set by quantitative methods. A rater will also have difficulty resolving particles smaller than 40 μm . Smaller particles must be determined by other than visual methods such as [D2276](#), [D5452](#) or chemical field tests listed in Manual 5.⁵

5.3 Experience has shown the visual appearance of fuel in a white porcelain bucket to be the most suitable method for the detection of dye contamination or other unusual discoloration. In the U.S., the white porcelain bucket is used to detect the dye.

6. Apparatus

6.1 *Cylindrical Clear Container*, such as:

6.1.1 *Clear Container*, with lid, capable of holding 750 mL (nominal 1 U.S. qt) of fuel and having a diameter of 100 mm \pm 10 mm (4 in. \pm 0.4 in.). There should be no gasket in the lid.

6.1.2 *Closed Circuit Sampler*, holding about 4 L (1 gal U.S.) of fuel and being permanently mounted to receive fuel from a fuel line or a storage tank and having inlet and outlet valves to control filling and emptying of the container. The sampler base is normally conical and incorporates the fuel inlet and outlet. The fill port is designed to cause the fuel to swirl around the sides of the clear glass tube. The circuit sampler may also contain hydrometer and chemical water detection ports.

6.2 *Appearance Card and Photographs*:

6.2.1 *Paper Card (Bar Chart)*, laminated in clear plastic having five parallel lines of different widths (see ASTM adjunct [ADJD417601](#)).

6.2.2 *Appearance Photographs*, a series of standard photographs of the bar chart through a series of samples of different haze levels, numbered from one through six. Photograph No. 1 is the clearest, while No. 6 represents the densest haze (see ASTM adjunct [ADJD417602](#)). A fuel sample rated clear and bright will have a rating of "one."

6.2.2.1 The differences between these haze levels are arbitrary and are not intended to represent equivalent increases in suspended water content or particulates. It is essential, therefore, that only the proper approved bar charts and photographs be used.

6.3 *Opaque Sample Containers*:

6.3.1 *White Bucket*, a circular bucket with straight but non-parallel sides and a flat bottom and a minimum capacity of 7.5 L (2.0 U.S. gal) and approximately 20 cm (8 in.) high, either coated with white porcelain enamel or made of stainless steel. Porcelain coatings must be free of dark spots, chips, or other surface damage, most particularly on the bottom of the bucket. Stainless steel buckets shall be made of a rust-resistant

⁵ Manual 5, *Aviation Fuel Quality Control Procedures*, 2nd Ed., ASTM International, W. Conshohocken, PA, 1995.