



**INTERNATIONAL STANDARD ISO 11925-2:2010**  
**TECHNICAL CORRIGENDUM 1**

Published 2011-01-15

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

**Reaction to fire tests — Ignitability of products subjected to  
direct impingement of flame —**

**Part 2:  
Single-flame source test**

**TECHNICAL CORRIGENDUM 1**

*Essais de réaction au feu — Allumabilité de produits soumis à l'incidence directe de la flamme —*

*Partie 2: Essai à l'aide d'une source à flamme unique*

*RECTIFICATIF TECHNIQUE 1*

Technical Corrigendum 1 to ISO11925-2:2010 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 1, *Fire initiation and growth*.

---

*Page 2, 3.2*

Replace the second indent in item b) with the following (thus replacing 10 m with 10 mm):

- for a surface containing cracks, fissures or holes, these do not exceed 6,5 mm in width or 10 mm in depth, and that the total area of such cracks, fissures or holes at the surface does not exceed 30 % of a representative square area of 250 mm × 250 mm of the exposed surface