

\$4E J1991 AUG2011

Issued 1989-10 Stabilized 2011-08

Superseding J1991 FEB1999

Standard of Purity for Use in Mobile Air-Conditioning Systems

RATIONALE

The technical report covers technology, products, or processes which are mature and not likely to change in the foreseeable future.

STABILIZED NOTICE

This document has been declared "Stabilized" by the SAE Interior Climate Committee and will no longer be subjected to periodic reviews for currency. Users are responsible for verifying references and continued suitability of technical requirements. Newer technology may exist.

SAE Technical Standards Board Rules provide that: "This report is published by SAE to advance the state of technical and engineering sciences. The use of this report is entirely voluntary, and its applicability and suitability for any particular use, including any patent infringement arising therefrom, is the sole responsibility of the user."

SAE reviews each technical report at least every five years at which time it may be reaffirmed, revised, or cancelled. SAE invites your written comments and suggestions. Copyright © 2011 SAE International

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of SAE.

TO PLACE A DOCUMENT ORDER:

Tel: 877-606-7323 (inside USA and Canada) Tel: +1 724-776-4970 (outside USA)

Fax: 724-776-0790

Email: CustomerService@sae.org

http://www.sae.org

SAE values your input. To provide feedback on this Technical Report, please visit http://www.sae.org/technical/standards/J1991 201108

Foreword—Due to the CFC's damaging effect on the ozone layer, recovery/recycling of CFC-12 (R-12) used in mobile air-conditioning (A/C) systems is required to minimize system venting during normal service operations. Establishing recycle specifications for CFC-12 (R-12) assures that system operation with recycled CFC-12 (R-12) will provide the same level of performance as new refrigerant. Refrigerant that has been "reclaimed" must meet the appropriate ARI 700 purity specifications and must be processed by an off-site certified refrigerant reclaimer. Refrigerant that is "recycled" on-site for direct reuse must meet the purity specifications as identified in Section 3 which is less stringent than the ARI 700 requirements.

Extensive field testing with the EPA and the auto industry indicate that reuse of CFC-12 (R-12) removed from mobile A/C systems can be accepted, if the refrigerant is cleaned to a specific "recycled" standard. The purpose of this standard is to establish the specific minimum levels of CFC-12 (R-12) purity required for recycled R-12 removed from automotive A/C systems.

Scope—This information applies to refrigerant used to service automobiles, light trucks, and other vehicles
with similar CFC-12 (R-12) systems. Systems used on mobile vehicles for refrigerated cargo that have
hermetically sealed, rigid pipe, are not covered in this document.

2. References

- **2.1 Applicable Publications—**The following publications form a part of this specification to the extent specified herein. Unless otherwise indicated, the latest issue of SAE publications shall apply.
- 2.1.1 SAE PUBLICATIONS—Available from SAE, 400 Commonwealth Drive, Warrendale, PA 15096-0001.

SAE J1989—Recommended Service Procedure for the Containment of CFC-12 (R-12) SAE J1990—Extraction and Recycle Equipment for Mobile Automotive Air-Conditioning Systems

2.1.2 ARI PUBLICATION—Available from ANSI, 11 West 42nd Street, New York, NY 10036-8002.

ARI 700 Refrigerant Standard