

STANDARDS AUSTRALIA

Amendment No. 1
to
AS 2293.1—2005
Emergency escape lighting and exit signs for buildings
Part 1: System design, installation and operation

CORRECTION

The 2005 edition of AS 2293.1 is amended as follows; the amendments should be inserted in the appropriate places.

SUMMARY: This Amendment applies to Clauses 3.2.5, 4.3, 4.3.1, 4.3.2 5.4.5 and Tables 5.1, 5.2, 5.3, 5.4 and 5.5.

Published on 2 September 2008.

AMDT
No. 1
SEP
2008

Clause 3.2.5

Delete Item (b)(ii) and *replace* with the following:

- (ii) AS 62040.3:2002

AMDT
No. 1
SEP
2008

Clause 4.3

In the first paragraph, twice *replace* the word ‘initiated’ with ‘operated’.

AMDT
No. 1
SEP
2008

Clause 4.3.1

Delete the title and first paragraph and *replace* with the following:

4.3.1 Manually operated testing facilities

Where manually operated testing facilities are provided for discharge testing of the emergency escape luminaires and exit signs, these test facilities shall comply with the following:

AMDT
No. 1
SEP
2008

Clause 4.3.2

1 *Delete* the title and *replace* with the following:

4.3.2 Automatically operated testing facilities

2 *Delete* the fourth paragraph and *replace* with the following:

Provision shall be made on an automatic testing facility for an operator to undertake a discharge test at any time.

AMDT
No. 1
SEP
2008

Clause 5.4.5

Add a new clause as follows:

5.4.5 Protection against unauthorized removal of lamps

Where an emergency luminaire is mounted in a public area at a height of 2.4 m or lower, or an area subject to easy access, provision shall be made to protect it from unauthorized removal.

NOTES:

- 1 A non removable lamp, a wire guard or a diffuser would be considered to comply.
- 2 Premises such as schools, shopping centres, clubs and places of public entertainment are all considered to be public areas for the purposes of this clause.