

Rulings

RUL PL.20

Rulings to plumbing and piping systems Standards

Ruling 20: Size of drainage vents

(Ruling to AS 3500.2—1990)

Clause 3.10.3, Size of drainage vents

Enquiry:

What is the minimum size of a drainage vent located below ground in the following orientations?

- (a) On grade.
- (b) On vertical.

Ruling:

The drain vent branch may be DN 65 provided the drain vent is not greater than DN 65. See sketch below of a typical connection of vent to drain.

