



Designation: D7338 – 14 (Reapproved 2023)

Standard Guide for Assessment Of Fungal Growth in Buildings¹

This standard is issued under the fixed designation D7338; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This guide provides a compendium of information and a menu of options for assessment of fungal growth in buildings, but does not recommend a specific course of action. Due to the wide variety of fungal problems affecting buildings and their occupants, and the wide variety of buildings, it is not possible to describe a set of uniform steps that will always be performed during an assessment (that is, a standard practice); therefore the user of this guide must decide which steps are appropriate for a given situation or building.

1.2 This guide is specific to fungal growth, which is only one potential problem in a building environment. It may be part of, but is not intended to take the place of, a comprehensive indoor air quality investigation.

1.3 This guide describes minimum steps and procedures for collecting background information on a building in question, procedures for evaluating the potential for moisture infiltration or collection, procedures for inspection for suspect fungal growth, and procedures beyond the scope of a basic survey that may be useful for specific problems.

1.4 Assessments for fungal growth may be useful wherever fungal growth is suspected, excess moisture has been present or when there are concerns regarding potential fungal growth.

1.5 Periodic fungal assessment in buildings may be a component of preventative maintenance programs.

1.6 This guide is applicable to buildings including residential (for example, single or multi-family), institutional (for example, schools, hospitals), government, public assembly, commercial (for example, office, retail), and industrial facilities.

1.7 Recommendations for developing a sampling strategy or methods for the collection and analysis of fungal samples are beyond the scope of this guide. For recommendations for developing a sampling strategy, see Ref (1)², Chapter 10.

¹ This guide is under the jurisdiction of ASTM Committee D22 on Air Quality and is the direct responsibility of Subcommittee D22.08 on Assessment, Sampling, and Analysis of Microorganisms.

Current edition approved Jan. 1, 2023. Published February 2023. Originally approved in 2010. Last previous edition approved in 2014 as D7338 – 14. DOI:10.1520/D7338-14R23.

² The boldface numbers in parentheses refer to a list of references at the end of this standard.

1.8 Recommendations for remediation of fungal growth are beyond the scope of this guide.

1.9 This guide is not intended to supersede any government regulations governing the assessment of fungal growth in buildings.

1.10 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.11 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards*:³

[C755 Practice for Selection of Water Vapor Retarders for Thermal Insulation](#)

[C1699 Test Method for Moisture Retention Curves of Porous Building Materials Using Pressure Plates](#)

[D653 Terminology Relating to Soil, Rock, and Contained Fluids](#)

[D4442 Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials](#)

[E331 Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference](#)

[E547 Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Cyclic Static Air Pressure Difference](#)

[E631 Terminology of Building Constructions](#)

[E1105 Test Method for Field Determination of Water Penetration of Installed Exterior Windows, Skylights, Doors, and Curtain Walls, by Uniform or Cyclic Static Air Pressure Difference](#)

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

E1186 Practices for Air Leakage Site Detection in Building Envelopes and Air Barrier Systems

E1356 Test Method for Assignment of the Glass Transition Temperatures by Differential Scanning Calorimetry

E2128 Guide for Evaluating Water Leakage of Building Walls

E2270 Practice for Periodic Inspection of Building Facades for Unsafe Conditions

2.2 Non-ASTM Standards:

ANSI/GEI Standard MMS1001 Mold and Moisture Management Standard for New Construction

3. Terminology

3.1 Definitions:

3.1.1 *building envelope*, *n*—the outer elements of a building, both above and below ground, which divide the external from the internal environments. Commonly included are exterior walls, windows, doors, roofs and subfloors. **E631**

3.1.2 *bulk sample*, *n*—piece or quantity of bulk material that has been selected by some sampling process. **D653**

3.1.3 *capillary action*, *n*—(or *capillary migration*), of water, movement of water induced by the force of molecular attraction (surface tension) between the water and the material it contacts. **E631**

3.1.4 *condensation*, *n*—the process of converting a material in the gaseous phase to a liquid by decreasing temperature or by increasing pressure, or both. **E1356**

3.1.5 *exposure*, *n*—contact with a chemical, biological, physical, or other agent over a specified time period. **E1356**

3.1.6 *moisture content*, *n*—mass of water retained in the specimen divided by the dry mass of the specimen. **C1699**

3.1.7 *soot*, *n*—agglomerations of particles of carbon impregnated with tar, formed in the incomplete combustion of carbonaceous material. **E1356**

3.1.8 *vapor retarder*, *n*—a material or system that adequately impedes the transmission of water vapor under specified conditions. **E631**

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *boroscope*, *n*—device for internal inspection of difficult access locations such as wall cavities. Its long narrow tube contains a telescope system with a number of relay lenses. Light is provided via the optical path or fiber bundles.

3.2.2 *effloresce*, *v*—process by which water leaches soluble salts out of concrete or mortar for surface deposit. Also *efflorescence*, *n*, the name for these deposits.

3.2.3 *enzyme activity*, *n*—measure of the quantity of active enzyme present. Enzyme activity is essential to metabolism. Specifically, beta-N-acetylhexosaminidase (NAHA) is an enzyme present in all filamentous fungi, the measurement of which has been shown to be directly proportional to the amount of fungal biomass (see (2, 3)).

3.2.4 *fungus* (*s*), *fungi* (*pl.*), *n*—eukaryotic, heterotrophic, absorptive organisms that usually develop a rather diffuse, branched, tubular body (that is, network of hyphae) and usually reproduce by means of spores (4). The terms ‘mold’ and

‘mildew’ are frequently used by laypersons when referring to various fungal colonization.

3.2.5 *fungal spore*, *n*—general term for a reproductive structure in fungi. The spore is the structure that may be used for dissemination and reproduction, and may be resistant to adverse environmental conditions.

3.2.6 *hypha*, *n*—(pl. *hyphae*) tubular filament of fungal cells; the basic vegetative structure of the body of fungi (excluding yeasts).

3.2.7 *fungal growth*, *n*—vegetative portion of a fungus.

3.2.8 *infrared thermography*, *n*—thermal imaging, also called thermography, is the production of non-contact infrared, or “heat” pictures from which temperature measurements can be made.

3.2.9 *remediation*, *n*—to correct a problem. Related to fungal contamination, remediation includes correcting the water and moisture problems and the cleaning, removal, and/or replacement of mold-damaged or -contaminated materials.

3.2.10 *thermal bridging*, *n*—a phenomenon that occurs when heat is transferred at a substantially higher rate through a component, or assembly of components in a building envelope, than through the surrounding envelope area.

4. Summary of Guide

4.1 This guide presents a framework for locating and evaluating suspect fungal growth in buildings. Topics include background information, a basic assessment strategy and additional or advanced procedures.

4.2 Components of a basic assessment strategy may include (1) defining a scope of work, (2) collecting background information on the building and building systems, (3) formulation of a hypothesis or hypotheses, (4) an on-site survey for fungi, moisture dynamics, and heating, ventilating and air conditioning (HVAC) operation, and (5) documentation and reporting. Every component of the basic assessment shown below may be considered optional, since even some of the most basic steps may not be needed for certain well-defined situations.

4.3 When the information from the basic assessment is insufficient to support decision-making, additional procedures for a follow-up study may include: (1) characterizing site moisture in greater detail to assist in locating suspect fungal growth and controlling excess moisture; (2) accessing surfaces likely to harbor hidden fungal growth; and/or (3) sampling if necessary to test a specific hypothesis.

5. Significance and Use

5.1 This guide presents options for a systematic assessment of fungal growth in buildings.

5.2 This guide allows for site-specific flexibility and professional judgment in the choice of assessment procedures. It may not be necessary to perform in its entirety the basic assessment presented below to resolve a particular problem, for example, where fungal growth is localized and the source and extent of moisture is readily observable.

5.3 Conversely, no matter how comprehensive the survey, all fungal growth may not be identified or located in a fungal assessment.

5.4 Material removal or destructive investigation may be needed to access suspect surfaces.

5.5 Using the procedures described in this guide, the investigator may have obtained the data necessary to suggest specific recommendations, for example, how to remediate the observed fungal growth, or how to prevent further fungal growth, but those recommendations are beyond the scope of this guide.

5.6 Precautions may be needed to protect the assessor and building occupants where access may disturb fungal growth.

5.7 It is the user's responsibility to protect information that may be considered confidential, or private, or both, in accordance with project contract, corporate protocol, or local, state, and federal regulations, or a combination thereof.

5.8 It may be necessary to enlist other disciplines or trade expertise to assist in some steps of the assessment, but recommendations of when to enlist and whom to enlist are beyond the scope of this guide.

6. Background Information

6.1 Fungal Biology:

6.1.1 *Fungal Growth*—Fungi constitute over 25 % of the earth's biomass and are naturally present in every indoor and outdoor environment. Fungal spores (small propagules emitted from surface growth) are ubiquitous in air and settled dust. Fungal growth requires sufficient available moisture that is sustained for a sufficient time, a suitable food source/substrate, and a favorable range of temperature and pH. Both active and inactive (past) growth are termed "colonization" (5, 6, 7). Fungi can become dormant only to resume growth again in response to changing environmental conditions (for example, during periodic moisture intrusions).

6.1.2 *Fungal Spore Production*—Fungal spores are produced during active growth, but may be released into the air either during active growth or dormancy. Where fungal growth is located behind a wall, wall covering, ceiling, or carpet, spores may, but are less likely to reach the occupied space through this physical barrier (the potential for infiltration depends on pressure differentials, filtration, occupant activities, barrier openings and other pathways, etc.) (8, 9, 10, 3).

6.1.3 *Fungal Variation*—Types and concentrations of airborne or surface fungal spores at a given site as well as colonization vary substantially as they are influenced by many natural and manmade factors. Because of this variability, testing based on a limited number of samples may not be representative (6, 7).

6.2 Fungal Growth in a Building:

6.2.1 Indoor fungal growth is generally observed on surfaces subject to one or more of these conditions:

6.2.1.1 Condensation;

6.2.1.2 Spills, leaks or floods;

6.2.1.3 Consistent wetting, such as from landscape sprinklers;

6.2.1.4 Sustained elevated humidity;

6.2.1.5 Wicking due to capillary action from wet material.

6.2.2 Whether or not fungal growth actually occurs is dependent on:

6.2.2.1 Substrate porosity (for example, materials such as carpet tack strip and conventional drywall are highly susceptible),

6.2.2.2 Moisture resistance (for example, some drywall, gypsum plaster and sheathing products are modified to resist moisture or to limit water storage and/or are treated with an anti-microbial agent),

6.2.2.3 Moisture duration (for example, leaks which are single events or intermittent may dry before fungal growth is initiated; elevated humidity typically does not trigger fungal growth unless it is sustained),

6.2.2.4 Air circulation and dehumidification (for example, moisture may remained trapped when sealed behind baseboards, attached furniture or vapor barriers).

6.3 Detection of Fungal Growth:

6.3.1 *Fungus grows on an appropriate substrate.* Fungal growth is associated with biodegradable building materials (for example, paper covered gypsum wallboard, wood, ceiling tiles). It will not grow on inorganic materials (for example, masonry, concrete, gypsum plaster, stone, glass, ceramic tiles, grout) except where dust, dirt, grease or oil is present. It usually appears on surfaces which are wet or were previously wet. Fungal growth may pre-exist on wood surfaces not subject to water damage on-site. For example, wood used for building materials often becomes stained during tree growth or milling

6.3.2 *Fungal growth may be detected by simple visual inspection.* Fungal growth may appear as raised, powdery deposits, rings or colored spots which may be black, gray, white, green, red, resembling cotton, velvet, leather, or powder. When rubbed, dried fungal growth tends to spread or smear as a powder.

6.3.3 *Discoloration is not necessarily fungal growth.* The following surface markings should not be categorized as suspect fungal growth: yellow/brown water stains, scuffs, soot, dye, dust, ghosting (dust deposits form an outline on a cool surface), efflorescence, adhesives, and other residues of occupancy, maintenance, or construction.

6.3.4 *Visual detection of fungal growth is not always definitive.* Where the origin of discoloration or staining is not clearly fungal or non-fungal to the investigator, the discoloration should be considered suspect fungal growth. In some cases, an ambiguous appearance may be resolved by comparing the suspect surface with the same material which has not been subjected to wetting to determine if the suspect color or texture was pre-existing. If essential to the assessment conclusions, the discoloration may be confirmed (see below).

6.3.5 *Visual detection of fungal growth may not always be possible even when exposed.* Very early stages of fungal growth may not be visible to the unaided eye. Visual detection of fungal growth may be difficult where substrate color is similar (for example, black on black) or where discoloration is covered by dust or debris.

6.3.6 *Fungal growth may be inaccessible or hidden.* Many surfaces in a building cannot be examined without considerable