



Designation: D4870 – 22



Designation: 375/11 (2021) and 390/11 (2017)

Standard Test Method for Determination of Total Sediment in Residual Fuels^{1,2}

This standard is issued under the fixed designation D4870; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This test method covers the determination of total sediment up to 0.40 % m/m for distillate fuel oils containing residual components and to 0.50 % m/m in residual fuel oils having a maximum viscosity of 55 cSt (mm^2/s) at 100 °C. Some fuels can exceed the maximum filtration time specified in this test method due to factors other than the presence of significant quantities of insoluble organic or inorganic material. This test method can be used for the assessment of total sediment after regimes of fuel pretreatment designed to accelerate the aging process.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.* For specific warning statements, see 7.2, 7.3, Annex A1, and X1.6.1.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM International Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of ASTM Subcommittee D02.14 on Stability, Cleanliness and Compatibility of Liquid Fuels. The technically equivalent standard as referenced is under the jurisdiction of the Energy Institute Subcommittee SC-B-5.

Current edition approved Dec. 1, 2022. Published December 2022. Originally approved in 1988. Last previous edition approved in 2018 as D4870 – 18. DOI: 10.1520/D4870-22.

² This test method has been developed through the cooperative effort between ASTM and the Energy Institute, London. ASTM and IP standards were approved by ASTM and EI technical committees as being technically equivalent but that does not imply both standards are identical.

2. Referenced Documents

2.1 ASTM Standards:³

D4057 Practice for Manual Sampling of Petroleum and Petroleum Products

D4175 Terminology Relating to Petroleum Products, Liquid Fuels, and Lubricants

D4177 Practice for Automatic Sampling of Petroleum and Petroleum Products

E1 Specification for ASTM Liquid-in-Glass Thermometers

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this test method, refer to Terminology D4175.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *total sediment, n*—the sum of the insoluble organic and inorganic material that is separated from the bulk of the residual fuel oil by filtration through a Whatman GF/A filter medium, and that is also insoluble in a predominantly paraffinic solvent.

4. Summary of Test Method

4.1 A weighed quantity (10 g) of the oil sample is filtered through the prescribed apparatus at 100 °C. After solvent washing and drying the total sediment on the filter medium is weighed. The test is to be carried out in duplicate.

5. Significance and Use

5.1 Appreciable amounts of sediment in a residual fuel oil can cause fouling of facilities for handling, and give problems in burner mechanisms. Sediment can accumulate in storage tanks, on filter screens, or on burner parts, resulting in obstruction of the flow of oil from the tank to the burner.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard

6. Apparatus

6.1 *Filtration Apparatus*, constructed of brass, with copper steam coils attached, suitably supported above a vacuum flask appropriately protected against the effects of implosion. See Figs. 1 and 2.

6.2 *Temperature Measuring Device*, capable of measuring the temperature in the range from 95 °C to 105 °C with an accuracy of 0.5 °C.

6.3 *Oven*, electric, capable of maintaining a temperature of 110 °C ± 1 °C. The oven should be capable of safely evaporating the solvent without risk of fire.

6.4 *Stirring Rod*, glass or polytetrafluoroethylene (PTFE) approximately 150 mm in length and 3 mm in diameter.

6.5 *Beaker*, glass, 30 mL capacity, either squat form with lip or conical.

6.6 *Small Dishes*, such as watch glasses or Petri dishes.

6.7 *Hotplate*, electric.

6.8 *Steam Generator*, to provide steam at 100 °C ± 1 °C.

6.9 *Vacuum Source*, capable of providing the specified vacuum.

6.10 *Vacuum Gauge*, capable of measuring the specified vacuum.




FIG. 2 Arrangement of Filtration Apparatus

6.11 *Filter Medium*, Whatman glass fiber filter medium, Grade GF/A, 47 mm diameter.

6.12 *High Speed Mixer*, any convenient type, minimum speed 400 r/min.

6.13 *Desiccator*.

6.14 *Cooling Vessel*, a desiccator or other type of tightly covered vessel for cooling the filter media before weighing. The use of a drying agent is not recommended.




FIG. 1 Detail of Filtration Cell

6.15 *Syringe or Graduated Wash Bottle*, minimum capacity 25 mL, graduated in 0.5 mL increments.

6.16 *Forceps*, spade-ended.

7. Reagents and Materials

7.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents shall conform to the specifications of the committee on Analytical Reagents of the American Chemical Society, where such specifications are available.⁴ Other grades may be used, provided it is first ascertained that the reagent is of sufficiently high purity to permit its use without lessening the accuracy of the determination.

7.2 *Normal Heptane*, minimum 99.75 % purity. (**Warning**—Flammable, vapor harmful if inhaled. See A1.1.)

7.3 *Toluene*, at least reagent grade purity. (**Warning**—Flammable, vapor harmful. See A1.2.)

7.4 *Wash Solvent*, consisting of 85 % by volume *n*-heptane (7.2) and 15 % by volume toluene (see 7.3).

8. Sampling

8.1 Sample in accordance with Practice D4057 or Practice D4177.

9. Procedure

9.1 *Sample Preparation*—Mix the whole sample, as received, thoroughly using a high speed mixer when practicable, for 30 s. In all cases a sample taken on a glass or PTFE rod dipped to the bottom of the container must show a homogeneous appearance. For fuels with a high wax content (high pour point), or of very high viscosity, the sample must be heated before stirring. The temperature must be either 15 °C above the pour point in the case of low viscosity fuels, or that equivalent to 150 cSt to 250 cSt in the case of high viscosity fuels. In no case should the temperature exceed 80 °C.

9.2 *Filter Preparation*—For each test, dry two filter media for 20 min in the oven at 110 °C. Transfer each filter medium, separately, rapidly to a cooling vessel and allow to cool to room temperature for 20 min. Weigh each filter medium to the nearest 0.0001 g.

NOTE 1—The Whatman GF/A filter media are fragile and are to be handled with care. Before use, check each medium for consistency, and the possible presence of small defects (holes).

NOTE 2—For convenience, place the filters on numbered small dishes (6.6) during drying and cooling.

9.3 *Apparatus Assembly*—Before use, check that the filter support screen is clean. If necessary, the screen must be cleaned by boiling in a high boiling point aromatic solvent. When more than 2 % of the sinter area remains blocked by particulate matter after such cleaning, discard the screen and install a new one.

⁴ ACS Reagent Chemicals, Specifications and Procedures for Reagents and Standard-Grade Reference Materials, American Chemical Society, Washington, DC. For suggestions on the testing of reagents not listed by the American Chemical Society, see *Analar Standards for Laboratory Chemicals*, BDH Ltd., Poole, Dorset, U.K., and the *United States Pharmacopeia and National Formulary*, U.S. Pharmacopeial Convention, Inc. (USPC), Rockville, MD.

9.3.1 The filtration unit must be clean and dry before assembly. Stack the two previously dried and weighed filter media on top of the sinter support with the mesh imprint side down, using forceps. Apply slight vacuum to aid in centering the filter media, and place the top portion of the filtration apparatus carefully on to the media before clamping. Shut off the vacuum and pass steam at 100 °C ± 1 °C through the heating/cooling coils for 10 min prior to sample addition.

9.4 *Sample Addition*—Into a 30 mL beaker, pour approximately 11 g of the fuel sample prepared as described in 9.1 and weigh to the nearest 0.01 g. Connect the vacuum source and apply vacuum to an absolute pressure of 40 kPa ± 2 kPa minimum (61.3 kPa vacuum). Heat the contents of the beaker to 100 °C ± 2 °C. Then transfer the contents at 100 °C ± 2 °C (Note 3) to the center of the filter medium, taking care that no sample touches the walls during transfer (Note 4). Reweigh the beaker to the nearest 0.01 g. The quantity transferred should be 10 g ± 0.5 g. When filtration is not complete in 25 min, discontinue the test and repeat using 5 g ± 0.3 g of sample. If filtration is still not complete in 25 min, report the result as *filtration exceeds 25 min*.

NOTE 3—It is expedient to weigh the beaker plus stirrer plus temperature measurement device before and after transfer to avoid errors incurred by attempting to obtain a net weight. Any convenient means of heating the fuel sample to 100 °C ± 2 °C may be used, such as hot plate, water or oil bath, or an oven when equipped with a suitable stirrer. Samples that overheat above 105 °C must be discarded and not reused.

NOTE 4—For samples of high viscosity or high sediment, level filtration will be aided by small stage or even dropwise addition. It is preferable to avoid complete coverage of the filter medium with unfiltered oil sample. For samples of low filtration rate the pressure of 40 kPa ± 2 kPa should be maintained for the 25 min period.

9.5 *Filter Washing*—When the filtration is complete and the upper filter medium appears dry, continue the steam and vacuum for a further 5 min. Discontinue the steam supply and cool the apparatus by passing tap water through the coils. Wash the filtration unit carefully with two portions of 25 mL ± 1 mL of the wash solvent from a syringe or graduated wash bottle with a fine nozzle, taking care to remove any adhered sample from the wall of the upper part of the apparatus. Carefully remove the top portion of the filtration unit and wash the rim of the filter with a further 10 mL ± 0.5 mL of the wash solvent in a similar manner. Finally wash the whole of the filter medium area with 10 mL ± 0.5 mL of *n*-heptane.

NOTE 5—If the sample filters very rapidly, the vacuum should be released before the first solvent washing, to ensure complete coverage of the filter medium area by solvent. The vacuum should then be gently reapplied for the subsequent operations.

9.6 *Apparatus Disassembly*—After the filter medium appears dry, discontinue the vacuum supply. Using the forceps, carefully remove each filter medium separately and transfer them to the oven at 110 °C. Dry for 20 min and quickly transfer them to the cooling vessel (6.14). Allow them to cool to room temperature for 20 min and reweigh them to the nearest 0.0001 g.

10. Calculation

10.1 Calculate the mass percentage of total sediment for each test specimen using Eq 1. For each test specimen with a