



Designation: D6071 – 14 (Reapproved 2022)

Standard Test Method for Low Level Sodium in High Purity Water by Graphite Furnace Atomic Absorption Spectroscopy¹

This standard is issued under the fixed designation D6071; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the determination of trace sodium in high purity water. The method range of concentration is 1 to 40 $\mu\text{g/L}$ sodium. The analyst may extend the range once its applicability has been ascertained.

NOTE 1—It is necessary to perform replicate analysis and take an average to accurately determine values at the lower end of the stated range.

1.2 This test method is a graphite furnace atomic absorption spectrophotometric method for the determination of trace sodium impurities in ultra high purity water.

1.3 This test method has been used successfully with a high purity water matrix.² It is the responsibility of the analyst to determine the suitability of the test method for other matrices.

1.4 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.03 on Sampling Water and Water-Formed Deposits, Analysis of Water for Power Generation and Process Use, On-Line Water Analysis, and Surveillance of Water.

Current edition approved Nov. 1, 2022. Published December 2022. Originally approved in 1996. Last previous edition approved in 2014 as D6071 – 14. DOI: 10.1520/D6071-14R22.

² RP2712 Sub Program—Grab Sample Method Validation Report Results, Electric Power Research Institute, Palo Alto, CA, 1987.

2. Referenced Documents

- 2.1 *ASTM Standards*:³
 - D1066 Practice for Sampling Steam
 - D1129 Terminology Relating to Water
 - D1192 Guide for Equipment for Sampling Water and Steam in Closed Conduits (Withdrawn 2003)⁴
 - D1193 Specification for Reagent Water
 - D2777 Practice for Determination of Precision and Bias of Applicable Test Methods of Committee D19 on Water
 - D3370 Practices for Sampling Water from Flowing Process Streams
 - D3919 Practice for Measuring Trace Elements in Water by Graphite Furnace Atomic Absorption Spectrophotometry
 - D4453 Practice for Handling of High Purity Water Samples
 - D5810 Guide for Spiking into Aqueous Samples
 - D5847 Practice for Writing Quality Control Specifications for Standard Test Methods for Water Analysis

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this test method, refer to Terminology D1129.

4. Summary of Test Method

4.1 Sodium is determined by atomic absorption utilizing a graphite furnace for sample atomization.

4.2 A sample volume of several microlitres, depending upon the concentration of the analyte, is deposited on a graphite tube housed within an electrical furnace, and the system is heated in an inert gas environment. The sample is evaporated to dryness, ashed (charred or pyrolyzed), and atomized.

4.3 Ground-state atoms are produced during the atomization stage of the temperature program. The ground-state atoms

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ The last approved version of this historical standard is referenced on www.astm.org.

absorb the energy at a specific wavelength produced from a source as they are bombarded by the energy. The amount of energy absorbed is proportional to the concentration of the analyte in the sample.

4.4 The absorption signal produced during atomization is recorded on a chart recorder or stored in microprocessor memory and compared to those standards taken through the same process by means of an analytical curve.

4.5 A general guide for graphite furnace applications is given in Practice [D3919](#).

5. Significance and Use

5.1 Small quantities of sodium, 1 to 10 $\mu\text{g/L}$, can be significant in high pressure boiler systems and in nuclear power systems. Steam condensate from such systems must have less than 10 $\mu\text{g/L}$. In addition, condensate polishing system effluents should have less than 1 $\mu\text{g/L}$. Graphite furnace atomic absorption spectroscopy (GFAAS) represents technique for determining low concentrations of sodium.

6. Interferences

6.1 No known interferences from other constituents are found in high purity waters.

6.2 For a complete discussion on interferences with graphite furnace procedures, refer to Practice [D3919](#).

6.3 Sodium is a common contaminant in many reagents. The analyst must ensure that the quality of the reagent used in the procedure is sufficiently high to determine trace levels of sodium.

6.4 All plasticware and apparatus must be cleaned and maintained to eliminate high background levels of sodium when determining trace levels.

6.5 Airborne particulates are a potential interference with the analysis of sodium by GFAAS. The user must ensure that all plasticware and other equipment is capped or stored in air tight containers.

7. Apparatus

7.1 *Atomic Absorption Spectrophotometer*, with the capability of setting the following instrumental parameters:

Metal	Wavelength, nm	Slit width (SBW), nm
Sodium	589.0	0.5

NOTE 2—The manufacturer's instructions should be followed for all instrument parameters.

7.2 *Hollow Cathode Lamp*, for sodium.

7.2.1 Multielement hollow cathode lamps may be used if the analyst ensures the necessary sensitivity is available for the low level determination.

7.3 *Graphite Furnace*, capable of reaching temperatures sufficient to atomize the elements of interest. Maximum sensitivity will be obtained when atomization temperatures are reached rapidly.

7.4 *Graphite Tubes*, compatible with the furnace device. Standard graphite tubes of uncoated graphite should be used. When maximum sensitivity is required, the analyst may choose to use pyrolytically coated graphite tubes.

7.5 *Autosampler*, compatible with the graphite furnace device may be used to increase the precision of the injection or dispensing the sample into the graphite tube.

7.6 *Pipets*, microlitre with disposable plastic tips. Sizes may vary from 1 to 100 μL , as required.

7.7 *Flasks*, plastic, volumetric. Sizes may vary from 100 to 1000 mL.

7.8 *Strip Chart Recorder (Computing Device with Display)*—The user must keep a permanent record of the data in addition to instrument problems (drift, incomplete atomization, changes in sensitivity, etc.).

7.8.1 The strip chart recorder with a response of 0.2 s or less for full scale deflection is recommended to ensure accuracy.

8. Reagents and Materials

8.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents shall conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society.⁵ Other grades may be used, provided it is first ascertained that the reagent is of sufficiently high purity to permit its use without lessening the accuracy of the determination.

8.2 *Purity of Water*—Reference to water that is used for reagent preparation, rinsing or dilution shall be understood to mean water that conforms to the quantitative specifications of Type I reagent water of Specification [D1193](#).

8.3 *Sodium Solution, stock (1 mL = 1000 $\mu\text{g Na}$)*—Dissolve 2.542 g of sodium chloride in water and dilute to 1 L.

8.4 *Sodium Solution, intermediate (1 mL = 10.0 $\mu\text{g Na}$)*—Dilute 10.0 mL of stock sodium solution from [8.3](#) to 1 L with water.

8.5 *Sodium Solution, standard (1 mL = 0.05 $\mu\text{g Na}$)*—Dilute 5 mL of intermediate sodium solution from [8.4](#) to 1 L with water.

NOTE 3—Alternatively, the analyst may purchase a commercially available standard (1 mL = 1000 $\mu\text{g Na}$). Additional dilution will be necessary to obtain the stock sodium solution concentration in [8.3](#).

8.6 *Argon*, 99.99 % pure.

9. Sampling

9.1 Collect the sample in accordance with Practices [D1066](#) and [D3370](#) or Specification [D1192](#).

9.2 Samples should be collected in polystyrene, TFE-fluorocarbon or polypropylene bottles only. Do not use glass or polyethylene containers. The containers should be rinsed with Type I water. The container should be stored prior to use by either air drying and capping or filling with Type I water and capping. For further details, see Practice [D4453](#).

⁵ *ACS Reagent Chemicals, Specifications and Procedures for Reagents and Standard-Grade Reference Materials*, American Chemical Society, Washington, DC. For suggestions on the testing of reagents not listed by the American Chemical Society, see *Analar Standards for Laboratory Chemicals*, BDH Ltd., Poole, Dorset, U.K., and the *United States Pharmacopeia and National Formulary*, U.S. Pharmacopeial Convention, Inc. (USPC), Rockville, MD.