



Designation: E3118/E3118M – 22

Standard Test Methods to Evaluate Seismic Performance of Suspended Ceiling Systems by Full-Scale Dynamic Testing ¹

This standard is issued under the fixed designation E3118/E3118M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

The response of nonstructural components, such as suspended ceiling systems, can significantly affect the functionality of a building after an earthquake, even when the structural components are undamaged.

Traditional suspended ceiling systems, which consist of typical direct hung “T” shaped main runners and cross tees, are installed in accordance with the prescriptive requirements contained in Practice E580/E580M, the applicable sections of the International Building Code, and ASCE/SEI 7. Specification C635/C635M, Test Methods E3090/E3090M, and Practice C636/C636M cover suspension systems and do not address seismic restraint of suspension systems or the performance of the ceiling panels. The performance of these traditional ceiling suspension systems is determined by mechanical testing of the connection’s strengths and the load-carrying capability of the suspension members. Practice E580/E580M contains specific instructions concerning the placement of hanger wires, perimeter fastening, and seismic bracing.

There are nontraditional suspended ceiling systems that do not consist of the typical direct hung “T” members. Connection strengths of the structural suspension members are not directly related to the anticipated performance of the system under earthquake loads. In addition, the ceiling panels or tiles are not always supported on all four sides of the suspension members. The integrity of ceiling systems depends on the ability of the ceiling infill panels to remain in place during an earthquake and on the structural integrity of the suspension system. These test methods provide a means to evaluate the performance of traditional suspended ceilings, as well as many of these nontraditional type ceiling systems.

1. Scope

1.1 These test methods help evaluate the performance of a full-scale suspended ceiling system during a seismic event using a dynamic seismic simulator (shake table).

1.2 These full-scale procedures are not the only available procedures for evaluating the seismic performance of ceiling systems. These tests do not preclude the use of other small-scale or full-scale component or system testing.

1.3 These test methods contain two independent procedures.

1.3.1 Comparative method where the level of performance of an experimental system is compared to that of a control test system under the same set of conditions.

1.3.2 Non-comparative method where a single test is conducted to establish the level of performance of an experimental system.

1.4 These test procedures are valid and useful for all types of suspended ceiling systems.

1.5 The text of this standard uses notes and footnotes that provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the standard.

1.6 The values stated in either SI units or inch-pound units are to be regarded separately as standard. Within the text, the SI units are shown in brackets. The values stated in each system are not necessarily exact equivalents; therefore, to ensure conformance with the standard, each system shall be used independently of the other, and values from the two systems shall not be combined.

¹ These test methods are under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.11 on Horizontal and Vertical Structures/Structural Performance of Completed Structures.

Current edition approved Jan. 1, 2022. Published February 2022. Originally approved in 2020. Last previous edition approved in 2021 as E3118/E3118M–21. DOI: 10.1520/E3118_E3118M-22.

1.7 This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.

1.8 This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

2. Referenced Documents

2.1 ASTM Standards:²

C635/C635M Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings

C636/C636M Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels

E580/E580M Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions

E631 Terminology of Building Constructions

E3090/E3090M Test Methods for Strength Properties of Metal Ceiling Suspension Systems

2.2 Other Standards:

AC156 Seismic Certification by Shake-table Testing of Non-structural Components³

ASCE/SEI 7 Minimum Design Loads and Associated Criteria for Buildings and Other Structures⁴

International Building Code⁵ Chapter 16, Structural Requirements

3. Terminology

3.1 *Definitions*—For definitions related to building construction, see Terminology **E631**.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *comparative testing, v*—testing where the level of performance of an experimental system is compared to that of a control system under the same set of conditions.

3.2.2 *control system, n*—an existing, code compliant, suspended ceiling system with an established level of performance.

3.2.2.1 *Discussion*—A suspended ceiling system constructed using code compliant components and in accordance with code compliant installation requirements.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from ICC Evaluation Service, LLC, 3060 Saturn Street, Suite 100, Brea, CA 92821, <https://icc-es.org>.

⁴ Available from American Society of Civil Engineers (ASCE), 1801 Alexander Bell Dr., Reston, VA 20191, <http://www.asce.org>.

⁵ Available from and a registered trademark of International Code Council (ICC), 500 New Jersey Ave., NW, 6th Floor, Washington, DC 20001, <http://www.iccsafe.org>.

3.2.3 *experimental system, n*—a suspended ceiling system with a level of performance that has not been established.

3.2.4 *grid component disengagement, n*—grid connection failure where main runner splice failure, tee-to-tee connection failure, and/or perimeter clip failure occurs.

3.2.5 *level of performance, n*—a boundary between acceptable and unacceptable performance of the system.

3.2.6 *non-comparative testing, v*—testing where a single test is conducted to establish the level of performance of an experimental system.

3.2.6.1 *Discussion*—Non-comparative testing can be used as supporting data for a certificate of conformance.

3.2.7 *panel loss, n*—a panel disengaging from the ceiling plane and falling to the floor.

3.2.8 *required response spectrum (RRS), n*—the required response spectrum generated using the formulas and normalized spectra detailed in AC156.

3.2.9 *test response spectrum (TRS), n*—the acceleration response spectrum that is developed from the actual time history of the motion of the seismic simulator test as measured by reference control accelerometers mounted on the shake table at a location near the base of the test frame.

3.2.10 *uniformly distributed weight, W_p, n*—the weight of the ceiling system, including the ceiling grid; ceiling panels; light fixtures; heating, ventilation, and air conditioning (HVAC) fixtures and ductwork; sprinklers; and piping; etc., or various combinations of these components that are supported by the test frame.

3.2.11 *white noise, n*—a broadband random motion used to establish the natural frequency and damping ratio of the ceiling test frame and the attached ceiling system.

3.2.11.1 *Discussion*—White noise is one test of resonant frequency search. It is also permitted to use the sine sweep tests, or equivalent, to the resonance tests.

4. Summary of Test Methods

4.1 *Procedure A – Comparative Test Method*—This method shall be used to compare the performance of a proposed experimental system to that of a control system of similar, uniformly distributed weight. The experimental system shall include all components of the ceiling system being evaluated. The experimental system is attached to a test frame, which is then attached to the seismic simulator, which transmits the motion of the simulator to the ceiling system. To be acceptable, the experimental system shall demonstrate equal to or superior performance to the control system when subjected to the same test protocol.

4.2 *Procedure B – Non-comparative Test Method*—This method utilizes a single assembly to establish the level of performance of a ceiling system. The experimental system shall include all components of the ceiling system being evaluated. The ceiling suspension system is attached to a test frame, which is then attached to the seismic simulator, which transmits the motion of the simulator to the ceiling system.