This Research Report is issued under the fixed designation RR: D01-1028. You agree not to reproduce or circulate or quote, in whole or part, this document outside of ASTM International Committee/Society activities, or submit it to any other organization or standards body (whether national, international or other) except with the approval of the Chairman of the Committee having jurisdiction and the written authorization of the President of the Society. If you do not agree to these conditions, please immediately destroy all copies of this document. *Copyright ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428. All rights reserved.* 

**19 November 1991** 

## Committee D01 on Paint and Related Coatings, Materials, and Applications Subcommittee D01.47 on Concrete, Stone and Masonry Treatments

Research Report D01-1028

Interlaboratory Study to Establish Precision Statements for ASTM D5095, Test for Determination of Nonvolatile Content of Silanes, Siloxanes, and Silane-Siloxane Blends Used in Masonry Water Repellent Treatments

**Technical contact:** 

Thomas J. Silva

ASTM International 100 Barr Harbor Drive West Conshohocken, PA 19428-2959



November 11, 1991

Ms. Dolores Collier ASTM 1916 Race Street Philadelphia, PA 19103-1187

Dear Ms. Collier:

I am the steward of ASTM D 5095-90, Standard Test Method of Determination of the Nonvolatile Content of Silanes, Siloxanes and Silane-Siloxane Blends Used in Masonry Water Repellent Treatments. I was informed by Scott Orthey of ASTM that I have not submitted the results from our round-robin testing and precision and bias statements for inclusion in a Research Report.

I have enclosed the above mentioned materials in this package. If you require any further information, please advise me at your earliest convenience.

Sincerely

Thomas J. Sliva

Assistant Technical

Director

201.47

Task Group No. D.01.47.03
Round Robin No. 3
Date June 27, 1989
T.G.Chairman Thomas J. Sliva

## DETERMINATION OF ACTIVE SOLIDS CONTENT IN SILANES AND SILANE\SILOXANE BLENDS IN MASONRY WATER REPELLENT COATINGS REPEATABILITY TESTS

	20010					
COOP	<u> Lab</u> 1	<u> Lab 2</u>	<u>Lab</u> 3	Lab 4	<u>Lab</u> 5	
1.	Silane A - Waterborne Initial Test					
	13.35	14.85	13.86	14.84	13.63	
	13.35	14.72	13.90	14.76	13.72	
	15.18	13.85	14.44	14.84	13.68	
				1404	13.00	
	Repeat Test					
	13.96	14.47	14.07	14.51	13.54	
	14.05	13.72	13.56	14.32	13.59	
	13.86	_	13.90	13.89	13.48	
					25110	
2.	Silane B - Solvent Initial Test					
	65.34	64.77	63.08	65.28	63.43	
	64.35	64.74	65.02	65.37	63.36	
	64.39	64.50	64.64	65.28	63.06	
	Repeat Test					
	64.36	64.35	64.25	65.31	62.16	
	64.07	65.34	64.88	65.11	62.13	
	64.11		64.33	64.89	63.15	
3.	Silane C	Silane C - Waterborne				
	Initial Test					
	27.35	27.93	27.38	28.41	26.61	
	28.35	27.87	29.33	28.49	27.26	
	29.04	27.83	27.51	28.32	27.22	
	Repeat Test					
	28.71	29.99	28.22	28.88	26.59	
	27.88	30.99	29.11	28.77	26.61	
	28.31		28.32	29.04	27.17	
_						
4.						
	Initial Test					
	63.35	65.28	63.86	65.38	63.69	
	65.02	65.04	63.22	65.43	63.75	
	62.71	65.00	63.32	65.55	63.83	
	Repeat Test					
	64.77	71.28	64.88	64.99	63.08	
	65.02	70.99	65.42	66.03	63.44	
	64.88		65.13	65.66	63.17	
		24	<b></b>		0011/	