

BSI

BS 4485 : Part 3 : 1988

UDC 66.045.53/.54

© British Standards Institution. No part of this publication may be photocopied or otherwise reproduced without the prior permission in writing of BSI

British Standard

Water cooling towers

Part 3. Code of practice for thermal and functional design

Tours de refroidissement par l'eau

Partie 3. Conception thermique et fonctionnelle — Code de bonne pratique

Wasserkühltürme

Teil 3. Leitfaden für die Bemessung unter thermischen und funktionalen Gesichtspunkten

Foreword

This Part of BS 4485, which has been prepared under the direction of the Civil Engineering and Building Standards Committee, deals with the thermal and functional design of natural draught, mechanical draught and factory prefabricated cooling towers. This Part of BS 4485 is a revision of BS 4485 : Part 3 : 1977, together with its Addendum No. 1 (1978) both of which are withdrawn. In this revision the following principal changes have been made.

- (a) The guidelines on water treatment have been expanded as these were not considered sufficient for good operating practice.
- (b) Reference has been made to the potential health hazard arising from the bacterial population of cooling towers, as it relates to the design of the towers. However, operational techniques for control in this area are outside the scope of this Part of BS 4485.
- (c) Factory prefabricated cooling towers previously dealt with in Addendum No. 1 to BS 4485 : Part 3 : 1977 have been covered by suitable modification of the main text of this Part of BS 4485.
- (d) Information to be supplied by the purchaser and the manufacturer, which was included in Addendum No. 1 to BS 4485 : Part 3 : 1977, now appears as appendix A in this Part of BS 4485 as it is considered relevant to all types of cooling towers.
- (e) Materials of construction have been omitted as these are dealt with in BS 4485 : Part 4*.
- (f) A new clause on maintenance has been added which was in Addendum No. 1 to BS 4485 : Part 3 : 1977.

This Part of BS 4485 provides information on design principles, siting and spacing. Guidance is given on specific thermal and hydraulic requirements, on mechanical equipment and on environmental aspects such as discharge into rivers and cooling tower noise.

The other Parts of BS 4485 are as follows.

- Part 1 Glossary of terms
- Part 2 Methods for performance testing
- Part 4 Structural design of cooling towers

Where necessary, definitions have been included in the revisions of BS 4485 : Parts 2, 3 and 4 so that when they have all been published BS 4485 : Part 1 can be withdrawn.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

* Under revision.

Contents

	Page		Page
Foreword		Inside front cover	
Committees responsible		Back cover	
Code of practice		Tables	
1 Scope	2	1 Symbols and units	2
2 Symbols and units	2	2 Standard reference sheet for physical dimensions	11
3 Thermal design principles	4	3 Addition of decibels	44
3.1 Cooling process	4	4 Typical corrections to obtain octave band spectra for various fan types	45
3.2 Heat transfer diagram for counterflow conditions	6	5 Tower noise calculation	47
3.3 Crossflow tower calculation	9	Figures	
3.4 Natural draught tower calculations	9	1 Air-water flow paths in crossflow, counterflow and mixed flow towers	5
4 Types of cooling tower and their relative merits	9	2 Conditions of air and water in a cooling tower	6
4.1 General	9	3 Heat transfer diagram	6
4.2 Natural draught towers	11	4 Demand and characteristic curves	7
4.3 Mechanical draught towers	11	5 Performance curves for mechanical draught tower	8
5 Siting, spacing and environmental considerations	13	6 Performance curves for natural draught tower	8
5.1 General	13	7 Illustrations of basic types of cooling tower	10
5.2 Siting	13	8 Spacing	14
5.3 Spacing	13	9 Screen dry bulb and wet bulb isotherms for the UK for temperatures exceeded for the stated percentage of hours during June to September: period 1964-70	18
5.4 Environmental considerations	13	10 Mechanical draught counterflow tower: variation of tower size with cooling range, approach and wet bulb temperature	20
6 Guidance on specified operational requirements	17	11 Natural draught tower: variation of duty factor with cooling range, approach and wet bulb temperature (at constant 70 % r.h.)	21
6.1 Selection of design conditions (including probability curves)	17	12 Natural draught tower: variation of base diameter with circulating water flow corrected for duty factor	22
6.2 Guidance on the effect of variations of parameters	20	13 Drift eliminators	24
7 General thermal design	23	14 Basic recirculation allowance	25
7.1 Packings	23	15 Correction for cooling range and approach at 17 °C wet bulb temperature	26
7.2 Drift eliminators	23	16 Effect of altitude on heat transfer diagram	26
7.3 Recirculation	25	17 Natural draught tower: water distribution	28
7.4 Effect of altitude	26	18 Mechanical draught tower: water distribution	29
8 Hydraulic requirements of cooling towers	27	19 Variation in evaporation losses with ambient conditions	30
8.1 Water distribution	27	20 Purge, make-up and evaporation quantity balance	31
8.2 Water losses	30	21 Relation between purge ratio and concentration factor	31
8.3 Cold water basin design	32	22 Pond characteristic	33
8.4 Water quality	34	23 Anti-icing arrangements	36
8.5 Design for winter operation	35	24 Effect of salinity on heat transfer diagram	38
8.6 Use of saline water	37	25 Typical arrangement for induced draught fan drive assembly	39
8.7 Effect of salinity on heat transfer	37	26 Attenuation for distance from source	46
9 Mechanical equipment	38	27 Directivity correction	46
9.1 Fans	38		
9.2 Gearboxes	38		
9.3 Drive shafts and couplings	39		
9.4 Fan drivers	40		
9.5 Supports for mechanical equipment	40		
9.6 Vibration cut-out switches	40		
9.7 Keys and keyways	40		
10 Safety precautions	40		
10.1 General	40		
10.2 Mechanical plant	40		
10.3 Electrical plant	40		
10.4 Access	40		
10.5 Fire precautions	41		
11 Maintenance	41		
Appendices			
A Enquiry and suggested tender information for cooling towers	42		
B Evaluation of noise in cooling towers	44		