

# **Fire extinguishing installations and equipment on premises —**

## **Part 4: Specification for carbon dioxide systems**

ICS 13.220.20

# Committees responsible for this British Standard

The preparation of this British Standard was entrusted to Technical Committee FSH/18, upon which the following bodies were represented:

- British Fire Protection Systems Association
- Chief and Assistant Chief Fire Officers Association
- Health and Safety Executive
- Home Office
- Institute of Fire Safety
- Institution of Fire Engineers
- London Fire and Civil Defence Authority
- Loss Prevention Council
- Maritime and Coastguard Agency
- Ministry of Defence
- Society of Motor Manufacturers and Traders
- Warrington Fire Research Centre

This British Standard, having been prepared under the direction of the Health and Environment Sector Committee, was published under the authority of the Standards Committee and comes into effect on 15 August 2001

© The British Standards Institution 2012  
Published by BSI Standards Limited 2012

First published October 1979  
Second edition March 1986  
Third edition August 2001

The following BSI references relate to the work on this standard:

Committee reference FSH/18  
Draft for comment 00/541249 DC;  
11/30244843 DC

ISBN 978 0 580 75095 3

## Amendments issued since publication

Amd. No.	Date	Comments
A1	April 2012	See Foreword for details

# Contents

	Page
Foreword	iii
Introduction	1
1 Scope	1
2 Normative references	1
3 Terms and definitions	4
4 Characteristics and uses of carbon dioxide	5
5 Types of system	6
6 Planning	7
7 Specifications, plans and approvals	7
8 Commissioning and acceptance	8
9 Inspection, maintenance, testing and training	11
10 Total flooding systems	12
11 Local application systems	22
12 Manual hose systems	28
13 System components	29
14 System operation	30
15 Safety precautions	30
16 Carbon dioxide supply	36
17 Quantity of carbon dioxide	36
18 Storage containers	36
19 Pipework	38
20 Installation of pipework	42
21 Marking of pipework	45
Annex A (normative) Door fan test for determination of minimum hold time	46
Annex B (informative) Service schedule	52
Annex C (normative) Determination of carbon dioxide concentrations for flammable liquids and gases	53
Annex D (informative) Examples of calculation of carbon dioxide requirements	58
Annex E (informative) Determination of carbon dioxide pipe and orifice size	62
Bibliography	73
Figure 1 — Calculated CO <sub>2</sub> loss rate based on an assumed 21 °C temperature within the enclosure and 21 °C ambient outside	15
Figure 1a — Discharge rates versus perimeter enclosed	26
Figure 2 — Aiming position for angled discharge nozzles	28
Figure 3 — Label to be displayed at manual control	34
Figure 4 — Label to be displayed at entrances to hazard	35
Figure C.1 — Cup burner apparatus	57
Figure D.1 — Example printer with a large enclosure	59
Figure D.2 — Example paint spray booth, open front and open top	60
Figure D.3 — Example paint spray booth, open front, one open side and open top	61
Figure E.1 — Pressure drop in pipeline for 20.7 bar storage pressure	66
Figure E.2 — Pressure drop in pipeline for 51.7 bar storage pressure	67
Table 0 — Physical properties of carbon dioxide	6
Table 1 — Volume factors	17
Table 2 — Minimum carbon dioxide concentration for extinction	18
Table 3 — Design concentrations and flooding factors for specific hazards	19