

Code of practice for

**Fire extinguishing
installations and
equipment on
premises —**

Part 5: Halon systems

**Section 5.2 Halon 1211 total flooding
systems**

UDC 614.842.6:614.844.2

Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Fire Standards Committee (FSM/-) to Technical Committee FSM/13 upon which the following bodies were represented:

Association of Metropolitan Authorities
 British Automatic Sprinkler Association
 British Fire Protection Systems Association Ltd.
 British Fire Services' Association
 British Gas Corporation
 Chief and Assistant Chief Fire Officers' Association
 Confederation of British Industry
 Department of the Environment (Building Research Establishment, Fire Research Station)
 Department of the Environment (Property Services Agency)
 Department of Health and Social Security
 Department of Transport (Marine Directorate)
 Electricity Supply Industry in England and Wales
 Engineering Equipment and Materials Users' Association
 Fire Extinguishing Trades Association
 Fire Insurers' Research and Testing Organization (FIRTO)
 Fire Offices' Committee
 Fire Protection Association
 Greater London Council
 Health and Safety Executive
 Home Office
 Incorporated Association of Architects and Surveyors
 Institute of Petroleum
 Institution of Fire Engineers
 Institution of Gas Engineers
 Ministry of Defence
 National Coal Board
 Royal Institute of British Architects
 Society of Fire Protection Engineers
 Society of Motor Manufacturers and Traders Limited
 United Kingdom Atomic Energy Authority

This British Standard, having been prepared under the direction of the Fire Standards Committee, was published under the authority of the Board of BSI and comes into effect on 28 September 1984

© BSI 08-1999

The following BSI references relate to the work on this standard:
 Committee reference FSM/13
 Draft for comment 82/11026 DC

ISBN 0 580 13923 9

Amendments issued since publication

Amd. No.	Date of issue	Comments

Contents

	Page
Committees responsible	Inside front cover
Foreword	iii
<hr/>	
0 Introduction	1
1 Scope	1
2 Definitions	1
3 Characteristics of Halon 1211	2
4 Planning	3
5 Contract arrangements	4
6 System design	4
7 System operation	6
8 Enclosure characteristics	7
9 System components	8
10 System design procedure	11
11 Maintenance	12
12 Safety	13
<hr/>	
Appendix A Deep-seated fires	15
Appendix B Examples of calculation of Halon 1211 quantity where there is natural ventilation	15
Appendix C Examples of calculation of Halon 1211 quantity where there is forced ventilation	17
Appendix D Example of design calculation for balanced system	18
Appendix E Example of design calculation for unbalanced system	22
<hr/>	
Figure 1 — Isometric diagram of Halon 1211 pressurized to 25 bar at 21 °C	30
Figure 2 — Isometric diagram of Halon 1211 pressurized to 10.5 bar at 21 °C	31
Figure 3 — Pressure drop against mass flow rate for Halon 1211 in galvanized steel pipes	32
Figure 4 — Mass flow rate per unit area against nozzle pressure with Halon 1211/N ₂ for nozzle type A	33
Figure 5 — Mass flow rate per unit area against nozzle pressure with Halon 1211/N ₂ for nozzle type B	34
Figure 6 — Type A nozzle	35
Figure 7 — Type B nozzle	35
Figure 8 — Example of balanced system	36
Figure 9 — Example of Halon 1211 mass flow rate against container pressure for balanced system	37
Figure 10 — Example of unbalanced system	38
Figure 11 — Example of Halon 1211 mass flow rate against container pressure for unbalanced system	39
Figure 12 — Label to be displayed at manual control	40
Figure 13 — Label to be displayed at entrances to hazard	41
Figure 14 — Extended mass flow rate of Halon 1211 to maintain constant concentration in enclosures with openings	42
Figure 15 — Initial amounts of Halon 1211 to produce a 2.5 % (V/V) residual concentration in enclosures equipped for mechanical mixing	43
Figure 16 — Initial amounts of Halon 1211 to produce a 5 % (V/V) residual concentration in enclosures equipped for mechanical mixing	43