



## BSI Standards Publication

**Electric cables –  
Thermosetting insulated,  
armoured, fire-resistant  
cables of rated  
voltage 600/1 000 V for  
fixed installations, having  
low emission of smoke and  
corrosive gases when  
affected by fire –  
Specification**

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2015

Published by BSI Standards Limited 2015

ISBN 978 0 580 86731 6

ICS 13.220.99; 29.060.20

The following BSI references relate to the work on this document:

Committee reference GEL/20

Draft for comment 15/30301742 DC

**Publication history**

First published September 1996

Second edition, October 2000

Third edition, September 2009

Fourth (current) edition, November 2015

**Amendments issued since publication**

Date	Text affected
------	---------------

---

## Contents

1	Scope	1
2	Normative references	1
3	Terms and definitions	2
4	Voltage designation and fire resistance categories	3
5	Conductors	5
6	Insulation	5
7	Identification of cores	5
8	Laying-up	7
9	Bedding	7
10	Armour	8
11	Oversheath	9
12	Cable marking and additional information	9
13	End sealing	12
14	Schedule of tests	13
15	Test conditions	14
16	Routine tests	14
17	Sample tests	15
18	Type tests	17

### Annexes

Annex A (informative)	Guide to use and installation of cables	22
Annex B (normative)	Armour wire tests	28
Annex C (normative)	Compatibility test	30
Annex D (normative)	Abrasion resistance test	31
Annex E (normative)	Insulation resistance constant test on oversheath	31
Annex F (normative)	Resistance of armour	32
Annex G (informative)	Gross cross-sectional area of armour	33
Annex H (normative)	Test for shrinkage of oversheath	34
Annex I (normative)	Fire resistance test for category F2 – Additional provisions for cables with a diameter over 20 mm	35
Annex J (informative)	Guidance on type tests	37

Bibliography	41
--------------	----

### List of figures

Figure 1	– An example of the marking on the oversheath of the cable	11
Figure I.1	– Method of mounting a sample for test for resistance to fire with mechanical shock	36

### List of tables

Table 1	– Maximum permitted voltages against rated voltage of cable	4
Table 2	– Diameter of armour wire and mass of zinc coating	8
Table 3	– Schedule of tests	13
Table 4	– Two core 600/1 000 V cables with copper conductors	18
Table 5	– Three core 600/1 000 V cables with copper conductors	19
Table 6	– Four core 600/1 000 V cables with copper conductors	20
Table 7	– Five core 600/1 000 V cables with copper conductors	21
Table 8	– Multicore auxiliary 600/1 000 V cables with copper conductors	21
Table A.1	– Selection of cables for a.c. systems	23
Table A.2	– Test voltages after installation	28
Table B.1	– Temperature correction multiplication factors	29
Table C.1	– Compatibility requirements	30
Table D.1	– Vertical load requirements	31
Table F.1	– Maximum resistance of armour for two-, three-, four- and five-core cable	32