

BS 8552:2012



BSI Standards Publication

# Sampling and monitoring of water from building services closed systems – Code of practice

**bsi.**

...making excellence a habit.™

**Publishing and copyright information**

The BSI copyright notice displayed in this document indicates when the document was last issued.

© The British Standards Institution 2012

Published by BSI Standards Limited 2012

ISBN 978 0 580 70237 2

ICS 13.060.01

The following BSI references relate to the work on this standard:

Committee reference EH/3

Draft for comment 12/30215289 DC

**Publication history**

First published November 2012

**Amendments issued since publication**

<b>Date</b>	<b>Text affected</b>
-------------	----------------------

---

## Contents

Foreword *ii*

0	Introduction	1
1	Scope	1
2	Normative references	2
3	Terms and definitions	3
4	Design of the sampling programme	4
5	Sample locations and frequency	11
6	Sampling methodology	15
7	Documentation and reporting of results	22
8	Interpretation of results	23

### Annexes

Annex A (normative)	Sampling points	24
Annex B (normative)	Laboratory analytical methods for water quality sampling	25
Annex C (informative)	Method for detecting sulfate reducing bacteria (SRBs)	33
Annex D (informative)	Minimum performance requirements for on-site analysis	36
Annex E (normative)	Interpretation of results for pre-commission cleaning	36
Bibliography		39

### List of figures

Figure A.1	– Binder pressure test point for sampling dissolved oxygen	25
Figure E.1	– Interpretation of guidelines in relation to BSRIA BG29	38

### List of tables

Table 1	– Life stages of the closed-circuit water system	5
Table 2	– Suggested analyses	8
Table 2	– Suggested analyses	9
Table 3	– Examples of corrosion and scale inhibitors	10
Table 4	– Examples of analysis for permit to discharge application	11
Table 5	– Number of sample locations between filling/pressure testing and pre-commission cleaning	12
Table 6	– Minimum number of sample locations immediately post-clean and up to practical completion	14
Table A.1	– Selection of sampling points	24
Table B.1	– Reference analytical methods	32
Table C.1	– Probabilities of detecting the presence of SRBs using the five-day test	34
Table D.1	– Minimum performance requirements for on-site analysis of water in building services closed systems	36

### Summary of pages

This document comprises a front cover, an inside front cover, pages i to ii, pages 1 to 40, an inside back cover and a back cover.