

**ISO/IEC 14763-3**  
Edition 2.0 2014-06

**INFORMATION TECHNOLOGY – IMPLEMENTATION AND OPERATION  
OF CUSTOMER PREMISES CABLING –**

**Part 3: Testing of optical fibre cabling**

**CORRIGENDUM 1**

**Table 4 – Connecting hardware attenuation**

*Replace, in the second row,*

*in column 4, "SMF, Attenuation (random mated)", the existing value "0,30 dB max.", by "0,25 dB max."  
and*

*in column 5, "SMF, Attenuation (mated against reference)", the existing value "0,65 dB max.", by  
"0,75 dB max."*

**9.1.1.8 Treatment of permanent link test results**

*Replace, the existing formulae of bullets 1 and 2, by the following formulae:*

- for MMF: Limit =  $(2 \times 0,5 \text{ dB}) + \Sigma (\text{cable attenuation}) + \Sigma (\text{embedded connection attenuation})$ ;
- for SMF: Limit =  $(2 \times 0,75 \text{ dB}) + \Sigma (\text{cable attenuation}) + \Sigma (\text{embedded connection attenuation})$  (for reference connector).