



Tentative Interim Amendment

NFPA[®] 72[®]

National Fire Alarm and Signaling Code[®]

2022 Edition

Reference: 26.2.10(new)
TIA 22-2
(SC 21-4-11/ TIA Log #1549)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Add new section 26.2.10 to read as follows:

26.2.10 Emergency Monitoring Locations.

26.2.10.1 Upon an emergency declaration made by a national, state, or local authority that results in a business disruption event that inhibits normal operation of a supervising station, fire alarm system signals shall be permitted to be received at alternate locations other than a listed central station, proprietary supervising station, or remote supervising station.

26.2.10.2 The provision of 26.2.10.1 shall be permitted to remain in effect for the duration of the emergency declaration.

26.2.10.3 Specific authorization by local authorities having jurisdiction shall not be required for emergencies declared by a higher authority.

26.2.10.4 The provision of 26.2.10.1 shall be permitted to remain in place for not more than 30 calendar days following the termination of the declared emergency.

Issue Date: April 15, 2021

Effective Date: May 5, 2021

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2021 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION