

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE
NORME DE LA CEI

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC STANDARD

Modification

n° 1
Février 1986
à 1a


Publication 726
1982

Amendment

No. 1
February 1986
to

Transformateurs de puissance de type sec

Dry-type power transformers



Bureau Central de la Commission Electrotechnique Internationale

3, rue de Varembé
Genève, Suisse

TRANSFORMATEURS DE PUISSANCE DE TYPE SEC

PREFACE

La présente modification a été établie par le Comité d'Etudes n° 14 de la CEI: Transformateurs de puissance.

Le texte de cette modification est issu des documents suivants:

| Règle des Six Mois | Rapport de vote |
|--------------------|-----------------|
| 14(BC)61 | 14(BC)64 |

Pour de plus amples renseignements, consulter le rapport de vote mentionné dans le tableau ci-dessus.

Page 18

Tableau IV: Limites d'échauffement

Dans la colonne 2 de ce tableau, remplacer "185 (H)" par "180 (H)".

DRY-TYPE POWER TRANSFORMERS

PREFACE

This amendment has been prepared by IEC Technical Committee No. 14: Power Transformers.

The text of this amendment is based upon the following documents:

| Six Months' Rule | Report on Voting |
|------------------|------------------|
| 14(C0)61 | 14(C0)64 |

Further information can be found in the Report on Voting indicated in the table above.

Page 19

Table IV: Temperature-rise limits

In column 2 of this table, replace "185 (H)" by "180 (H)".
