



Standard Test Method for Total Mercury in Coal by the Oxygen Bomb Combustion/Atomic Absorption Method¹

This standard is issued under the fixed designation D 3684; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method describes a procedure for the analysis of total mercury in coal.

1.2 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.* Specific precautionary statements are given in 8.3.1.

1.3 The values stated in SI units (**IEEE/ASTM SI 10**) shall be regarded as the standard.

2. Referenced Documents

2.1 ASTM Standards:²

D 1193 Specification for Reagent Water

D 2013 Practice for Preparing Coal Samples for Analysis

D 3173 Test Method for Moisture in the Analysis Sample of Coal and Coke

D 3180 Practice for Calculating Coal and Coke Analyses from As-Determined to Different Bases

D 5142 Test Methods for Proximate Analysis of the Analysis Sample of Coal and Coke by Instrumental Procedures

E 144 Practice for Safe Use Of Oxygen Combustion Bombs
IEEE/ASTM SI 10 Standard for Use of International System of Units (SI): The Modern Metric System

2.2 ISO Standards

ISO 5725-6:1994 Accuracy of measurement methods and results-Part 6³

¹ This test method is under the jurisdiction of ASTM Committee D05 on Coal and Coke and is the direct responsibility of Subcommittee D05.29 on Major Elements in Ash and Trace Elements of Coal.

Current edition approved April 1, 2006. Published April 2006. Originally approved in 1978. Last previous edition approved in 2001 as D 3684 – 01.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from International Organization for Standardization (ISO), 1 rue de Varembe, Case postale 56, CH-1211, Geneva 20, Switzerland.

3. Summary of Test Method

3.1 Total mercury is determined in this test method by combusting a weighed sample in an oxygen bomb with dilute nitric acid absorbing the mercury vapors. The bomb is rinsed into a reduction vessel with dilute nitric acid, and the mercury is determined by the flameless cold vapor atomic absorption technique.

NOTE 1—Mercury and mercury salts can be volatilized at low temperatures. Precautions against inadvertent mercury loss should be taken when using this method.

4. Significance and Use

4.1 The possible emission of mercury that may be found in coal from coal combustion is an environmental concern.

4.2 When test portions are burned according to this procedure, the total mercury is quantitatively retained and is representative of concentrations in the whole coal.

5. Apparatus

5.1 *Combustion Bomb*—The combustion bomb shall be constructed of materials that are not affected by the combustion process or products. The bomb must be designed so that all liquid combustion products can be completely recovered by washing the inner surfaces. There must be no gas leakage during the test. The bomb must be capable of withstanding a hydrostatic pressure test to gage pressure of 20 MPa (approximately 3000 psig) at room temperature without stressing any of the parts beyond the elastic limit.

5.2 *Water Bath*—A container shall be large enough to hold the combustion bomb, and enough cooling water shall be used to dissipate the heat generated during the combustion process. The container should be designed to allow a constant flow of water around the combustion bomb.

5.3 *Combustion Crucibles*—Samples shall be burned in an open crucible of platinum, quartz, or acceptable base-metal alloy.

5.4 *Firing Wire*, 100 mm of either No. 34 B&S (0.160-mm) nickel-chromium alloy, No. 34 B&S iron, or No. 38 B&S (0.101-mm) gage platinum wire.

5.5 *Firing Circuit*—A 6- to 16-V alternating or direct current is required for ignition purposes with an ammeter or pilot light in the circuit to indicate when current is flowing. A stepdown transformer connected to an alternating current lighting circuit or batteries may be used. The ignition circuit switch shall be of the momentary double-contact type, normally open, except when held closed by the operator. The switch should be depressed only long enough to fire the charge.

5.6 *Analytical Balance*, with a sensitivity of 0.1 mg.

5.7 *Atomic Absorption Spectrophotometer*, with a flameless cold-vapor mercury analysis system comprised of either a closed recirculating system or an open one-pass system.

5.8 *Reduction Vessels*, biochemical oxygen demand (BOD) bottles, 300-mL capacity.

6. Reagents

6.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents shall conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society, where such specifications are available.⁴ Other grades may be used, provided it is first ascertained that the reagent is of sufficiently high purity to permit its use without lessening the accuracy of the determination.

6.2 *Reagent Water*—Reagent water, conforming to Type II of Specification D 1193, shall be used for preparation of reagents and washings of the bomb interior.

6.3 *Hydroxylamine Hydrochloride Solution (1.5 g/100 mL)*—Dissolve 1.5 g of hydroxylamine hydrochloride ($\text{NH}_2\text{OH}\cdot\text{HCl}$) in water and dilute to 100 mL.

6.4 *Mercury Standard Stock Solution [1000 ppm (1000 $\mu\text{g}/\text{mL}$)]*—Dissolve 1.080 g of mercury (II) oxide (HgO) in a minimum volume of HCl (1+1). Dilute to 1 L with water.

6.5 *Mercury Standard Solution [0.1 ppm ($\mu\text{g}/\text{mL}$)]*—Dilute 0.10 mL of mercury standard stock solution to 1 L with water. If micropipets are not available, this standard may be prepared by serial dilution of the mercury standard stock solution. Prepare the mercury standard solution daily.

6.6 *Nitric Acid (1+9)*—Dilute 100 mL of concentrated nitric acid (HNO_3 , sp gr 1.42) to 1 L with water.

6.7 *Oxygen*—Oxygen shall be free of combustible matter. Only oxygen manufactured from liquid air, guaranteed to be greater than 99.5 % pure, will meet this requirement.

6.8 *Potassium Permanganate Solution (5 g/100 mL)*—Dissolve 5 g of potassium permanganate (KMnO_4) in water and dilute to 100 mL.

6.9 *Stannous Chloride Solution (10 g/100 mL)*—Dissolve 10 g of stannous chloride dihydrate ($\text{SnCl}_2\cdot 2\text{H}_2\text{O}$) in 45 mL of concentrated hydrochloric acid (HCl, sp gr 1.19) and *cautiously* dilute to 100 mL with water.

7. Sample

7.1 Prepare the analysis sample in accordance with Method D 2013 by pulverizing the material to pass a 250- μm (No. 60) sieve.

7.2 Analyze separate test portions for moisture content in accordance with Test Methods D 3173 or D 5142 so that calculation to other bases can be made.

8. Procedure for Bomb Combustion

8.1 Thoroughly mix the analysis sample of coal in the sample bottle. Weigh a test portion of about 1 g, to the nearest 0.0001 g, into a preignited crucible.

8.2 Transfer 10 mL of $\text{HNO}_3(1+9)$ to the combustion bomb, attach the fuse wire to the bomb electrodes, place the crucible with sample into the electrode support of the bomb, and adjust the fuse wire to contact only the test portion.

8.3 Assemble the bomb in conformance with the manufacturer's directions and charge it with oxygen to a pressure between 2 to 3 MPa (20 and 30 atm). If the oxygen should exceed the specified pressure, stop, detach the filling connection, exhaust the bomb in the usual manner, and discard the test portion.

8.3.1 **Warning**—The following precautions are recommended for safe oxygen bomb operation. Additional precautions are given in Practice E 144.

8.3.1.1 The weight of the test portion and the pressure of the oxygen admitted to the bomb must not exceed the bomb manufacturer's recommendations.

8.3.1.2 Inspect the bomb parts carefully after each use. Check the bomb for thread wear on any closures; if an inspection reveals any wear, replace the worn parts or return the bomb to the factory for testing or replacement of the defective parts. It is a good practice to replace the O-rings and seals, inspect screw cap threads, and hydrostatically test the bomb as per the manufacturer's recommendations.

8.3.1.3 Equip the oxygen supply cylinder with an approved type of safety device, such as a reducing valve, in addition to the needle valve and pressure gage used in regulating the oxygen feed to the bomb. Valves, gages, and gaskets must meet industry safety code. Suitable reducing valves and adaptors for 2.0- to 3.4-MPa (300- to 500-psi) discharge pressures are obtainable from commercial sources of compressed gas equipment. Check the pressure gage periodically for accuracy.

8.3.1.4 During ignition of a test portion, the operator must not permit any portion of his body to extend over the oxygen bomb.

8.3.1.5 Exercise extreme caution when combustion aids are used so as not to exceed the bomb manufacturer's recommendations and to avoid damage to the bomb. Do not fire loose fluffy material such as unpeletted benzoic acid, unless thoroughly mixed with the test portion.

8.3.1.6 Admit oxygen slowly into the bomb so as not to blow powdered material from the crucible.

8.3.1.7 Do not fire the bomb if it has been filled to greater than 3-MPa (30-atm) pressure with oxygen, or the bomb has been dropped or turned over after loading, or there is evidence of a gas leak when the bomb is submerged in the oxygen bomb water.

⁴ *Reagent Chemicals, American Chemical Society Specifications*, American Chemical Society, Washington, DC. For suggestions on the testing of reagents not listed by the American Chemical Society, see *Analar Standards for Laboratory Chemicals*, BDH Ltd., Poole, Dorset, U.K., and the *United States Pharmacopeia and National Formulary*, U.S. Pharmacopeial Convention, Inc. (USPC), Rockville, MD.