



Standard Guide for Selection and Use of Neutron Sensors for Determining Neutron Spectra Employed in Radiation-Hardness Testing of Electronics¹

This standard is issued under the fixed designation E720; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This guide covers the selection and use of neutron-activation detector materials to be employed in neutron spectra adjustment techniques used for radiation-hardness testing of electronic semiconductor devices. Sensors are described that have been used at many radiation hardness-testing facilities, and comments are offered in table footnotes concerning the appropriateness of each reaction as judged by its cross-section accuracy, ease of use as a sensor, and by past successful application. This guide also discusses the fluence-uniformity, neutron self-shielding, and fluence-depression corrections that need to be considered in choosing the sensor thickness, the sensor covers, and the sensor locations. These considerations are relevant for the determination of neutron spectra from assemblies such as TRIGA- and Godiva-type reactors and from Californium irradiators. This guide may also be applicable to other broad energy distribution sources up to 20 MeV.

NOTE 1—For definitions on terminology used in this guide, see Terminology E170.

1.2 This guide also covers the measurement of the gamma-ray or beta-ray emission rates from the activation foils and other sensors as well as the calculation of the absolute specific activities of these foils. The principal measurement technique is high-resolution gamma-ray spectrometry. The activities are used in the determination of the energy-fluence spectrum of the neutron source. See Guide E721.

1.3 Details of measurement and analysis are covered as follows:

1.3.1 Corrections involved in measuring the sensor activities include those for finite sensor size and thickness in the calibration of the gamma-ray detector, for pulse-height analyzer deadtime and pulse-pileup losses, and for background radioactivity.

1.3.2 The primary method for detector calibration that uses secondary standard gamma-ray emitting sources is considered in this guide and in General Methods E181. In addition, an alternative method in which the sensors are activated in the known spectrum of a benchmark neutron field is discussed in Guide E1018.

1.3.3 A data analysis method is presented which accounts for the following: detector efficiency; background subtraction; irradiation, waiting, and counting times; fission yields and gamma-ray branching ratios; and self-absorption of gamma rays and neutrons in the sensors.

1.4 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 General considerations of neutron-activation detectors discussed in Practice E261, Test Method E262, and Guides E721 and E844 are applicable to this guide. Background information for applying this guide are given in these and other relevant standards as follows:

2.2 *ASTM Standards:*²

E170 Terminology Relating to Radiation Measurements and Dosimetry

E181 Test Methods for Detector Calibration and Analysis of Radionuclides

E261 Practice for Determining Neutron Fluence, Fluence Rate, and Spectra by Radioactivation Techniques

E262 Test Method for Determining Thermal Neutron Reaction Rates and Thermal Neutron Fluence Rates by Radioactivation Techniques

¹ This guide is under the jurisdiction of ASTM Committee E10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.07 on Radiation Dosimetry for Radiation Effects on Materials and Devices.

Current edition approved June 1, 2011. Published July 2011. Originally approved in 1980. Last previous edition approved in 2008 as E720 – 08. DOI: 10.1520/E0720-11.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- E263 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Iron
- E264 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Nickel
- E265 Test Method for Measuring Reaction Rates and Fast-Neutron Fluences by Radioactivation of Sulfur-32
- E266 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Aluminum
- E393 Test Method for Measuring Reaction Rates by Analysis of Barium-140 From Fission Dosimeters
- E496 Test Method for Measuring Neutron Fluence and Average Energy from $^3\text{H}(d,n)$ ^4He Neutron Generators by Radioactivation Techniques
- E704 Test Method for Measuring Reaction Rates by Radioactivation of Uranium-238
- E705 Test Method for Measuring Reaction Rates by Radioactivation of Neptunium-237
- E721 Guide for Determining Neutron Energy Spectra from Neutron Sensors for Radiation-Hardness Testing of Electronics
- E844 Guide for Sensor Set Design and Irradiation for Reactor Surveillance, E 706 (IIC)
- E944 Guide for Application of Neutron Spectrum Adjustment Methods in Reactor Surveillance, E 706 (IIA)
- E1018 Guide for Application of ASTM Evaluated Cross Section Data File, Matrix E706 (IIB)
- E1297 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Niobium

3. Significance and Use

3.1 Because of the wide variety of materials being used in neutron-activation measurements, this guide is presented with the objective of bringing improved uniformity to the specific field of interest here: hardness testing of electronics primarily in critical assembly reactor environments.

NOTE 2—Some of the techniques discussed are useful for 14-MeV dosimetry. See Test Method E496 for activation detector materials suitable for 14-MeV neutron effects testing.

NOTE 3—The materials recommended in this guide are suitable for ^{252}Cf or other weak source effects testing provided the fluence is sufficient to generate countable activities.

3.2 This guide is organized into two overlapping subjects; the criteria used for sensor selection, and the procedures used to ensure the proper determination of activities for determination of neutron spectra. See Terminology E170 and General Methods E181. Determination of neutron spectra with activation sensor data is discussed in Guides E721 and E944.

4. Foil Sets

4.1 Reactions Considered:

4.1.1 Neutron-induced reactions appropriate for this guide are listed in Table 1. The table includes most of the reactions used in this field. Those not marked with an asterisk are recommended because of their demonstrated compatibility with other reactions used in spectrum adjustment determinations. This compatibility is primarily based on experience with the ENDF/B-VI (1, 2), and IRDF-90 (3) cross-sections. These recommendations may change modestly as revisions are made in the ENDF/B and IRDF dosimetry cross sections. Other

reactions may be useful in particular circumstances with appropriate care. It is important that the user take full account of both the footnotes attached to each reaction and the discussions in the body of the text about individual reactions when implementing the foil-activation technique.

4.1.2 The four paired columns under the labels fast burst (4) and “TRIGA (5) Type” list the energy ranges within which 95 % of the response occurs for these two representative spectra. These limits are just a guide because the response often varies widely within each range. The response limits for an idealized fission spectrum with no $1/E$ tail can be much different (shifted toward higher energy) for resonance reactions. For example, in a Watt fission spectrum the $^{197}\text{Au}(n,\gamma)^{198}\text{Au}$ has a 95 % response between 5.0×10^{-2} and 2.7 MeV. The recommended foil mass column gives values that are designed to minimize self-absorption, self-shielding, and other corrections, provided the foils are 1.27 cm in diameter. The $E_i \cong 0$ fission foils, ^{235}U and ^{239}Pu , have similar cross-section shapes. However, the ^{235}U foil is preferred since it is less expensive and is much less of a health hazard than ^{239}Pu . In addition, when measuring soft (TRIGA) spectra, the ^{235}U foil is useful in determining the correction for the ^{235}U impurity in the ^{238}U foil (which is readily available with about 400 ppm or less ^{235}U impurity).

4.1.3 Although sulfur is listed and is used widely as a monitor foil, it is the only recommended sensor requiring beta particle detection and, therefore, requires a different calibration and counting technique. The $^{58}\text{Ni}(n,p)^{58}\text{Co}$ reaction has about the same threshold energy and, therefore, can be used instead of the $^{32}\text{S}(n,p)^{32}\text{P}$ if it acquires sufficient activity. Many facilities use sulfur as a routine monitor because its two-week half-life allows a convenient period for counting and permits reuse of the sensor after 6 to 9 months. Automated beta counters are commercially available. Neither nickel nor sulfur should be counted for the (n,p) reaction products immediately after irradiation because for nickel the ^{58}Co must build up through a metastable state, and for sulfur there are competing reactions. According to Test Method E264 the waiting period for ^{58}Co should be 4 days. For ^{32}P , Test Method E265 recommends waiting 24 h. Corrections can be made for shorter waiting periods.

4.1.4 In selecting dosimetry reactions one should consider the validation of the cross sections and associated uncertainty as demonstrated in the ^{235}U thermal fission and the ^{252}Cf spontaneous fission benchmark neutron fields. Ref (6) provides a recent comparison of the measured and calculated spectrum-averaged cross sections for these benchmark fields.

4.1.5 Some frequently used reactions have shown relatively consistent deviations of measured to calculated activity ratios in many different spectra determinations. For example, when ENDF/B-V cross sections are used in the reaction $^{63}\text{Cu}(n,\gamma)^{64}\text{Cu}$, the calculated activity is usually low, and an adjustment code will try to raise the spectrum in the vicinity of Cu resonances. In fact, however, this consistent behavior indicates that the tabulated cross-section values in some important energy region are too small. The analyst must then choose one of the following alternatives: (1) leave out reactions which have demonstrated consistent deviations; (2) seek better

TABLE 1 Activation Foils

Reaction	Fast Burst ^A		TRIGA Type ^A		E_{γ}^B , (keV)	Gamma Emission Probability ^B	Fast Fission Yield, ^C %	$T_{1/2}^B$	Recommended Foil Mass, g ^D	Footnotes
	E_L , MeV	E_H , MeV	E_L , MeV	E_H , MeV						
¹⁹⁷ Au(<i>n,γ</i>) ¹⁹⁸ Au	4.00 – 6	7.20 – 4	3.80 – 6	9.20 – 6	411.8025	95.54		2.6944 days	0.06	<i>E,F,G</i>
⁵⁹ Co(<i>n,γ</i>) ⁶⁰ Co	7.60 – 6	4.50 – 4	6.90 – 7	1.43 – 4	1173.2	99.85		5.2711 years	0.06	<i>E,G</i>
					1332.5	99.98				
⁵⁸ Fe(<i>n,γ</i>) ⁵⁹ Fe	1.00 – 6	2.10 + 0	5.25 – 7	1.00 – 2	1099.245	56.59		44.495 days	0.15	<i>E,H</i>
					1291.59	43.21				
⁵⁵ Mn(<i>n,γ</i>) ⁵⁶ Mn	5.25 – 7	6.60 – 1	4.75 – 7	1.10 – 3	846.76	98.85		2.57878 h	0.05	<i>E,F</i>
					1810.726	26.9				
⁶³ Cu(<i>n,γ</i>) ⁶⁴ Cu	1.15 – 6	2.30 + 0	5.25 – 7	9.60 – 3	1345.77	0.4743		12.700 h	0.15	<i>E</i>
²³ Na(<i>n,γ</i>) ²⁴ Na	6.30 – 7	2.00 + 0	5.25 – 7	3.00 – 3	1368.626	99.993		14.9574 h	0.10	<i>E,I,J</i>
					2754.1	99.872				
⁴⁵ Sc(<i>n,γ</i>) ⁴⁶ Sc	4.25 – 7	1.00 + 0	4.00 – 7	4.75 – 4	889.27	99.983		83.788 days	0.05	<i>E</i>
					1120.537	99.986				
²³⁵ U(<i>n, f</i>) ¹⁴⁰ La	9.20 – 2	4.70 + 0	6.30 – 4	3.80 + 0	1596.2	95.4	6.105	40.28 h	0.30	<i>E,K,L</i>
²³⁵ U(<i>n, f</i>) ⁹⁵ Zr	9.20 – 2	4.70 + 0	6.30 – 4	3.80 + 0	724.2	44.27	6.363	64.03 days	0.60	<i>E,L</i>
					756.7	54.4				
²³⁹ Pu(<i>n, f</i>) ¹⁴⁰ La	1.43 – 1	4.80 + 0	8.80 – 4	4.30 + 0	1596.2	95.4	5.326	40.28 h	1.00	<i>E,K,L</i>
²³⁹ Pu(<i>n, f</i>) ⁹⁵ Zr	1.43 – 1	4.80 + 0	8.80 – 4	4.30 + 0	724.2	44.1	4.685	64.02 days	0.60	<i>E,L</i>
					756.7	54.4				
⁹³ Nb(<i>n, n'</i>) ^{93m} Nb	8.40 – 1	5.70 + 0	1.00 + 0	5.50 + 0	16.5-19.6	11.0		16.12 years		<i>M</i>
¹⁰³ Rh(<i>n, n'</i>) ^{103m} Rh	5.50 – 1	5.70 + 0	6.90 – 1	5.70 + 0	39.8	0.068		56.1 min		<i>M</i>
²³⁷ Np(<i>n, f</i>) ¹⁴⁰ La	5.75 – 1	5.60 + 0	6.60 – 1	5.50 + 0	1596.2	95.4	5.489	40.28 h	0.60	<i>E,K,L,N</i>
²³⁷ Np(<i>n, f</i>) ⁹⁵ Zr	5.75 – 1	5.60 + 0	6.60 – 1	5.50 + 0	724.2	44.1	5.699	64.02 days	0.60	<i>E,L</i>
					756.7	54.4				
¹¹⁵ In(<i>n, n'</i>) ^{115m} In	1.00 + 0	6.00 + 0	1.20 + 0	5.80 + 0	336.2	45.9		4.49 h	0.12	
²³⁸ U(<i>n, f</i>) ¹⁴⁰ La	1.50 + 0	6.90 + 0	1.50 + 0	6.60 + 0	1596.2	95.4	5.948	40.28 h	1.00	<i>E,K,L,O</i>
²³⁸ U(<i>n, f</i>) ⁹⁵ Zr	1.50 + 0	6.90 + 0	1.50 + 0	6.60 + 0	724.2	44.1	5.105	64.02 days	1.00	<i>E,L</i>
					756.7	54.4				
²³² Th(<i>n, f</i>) ¹⁴⁰ Ba	1.50 + 0	7.40 + 0	1.50 + 0	7.10 + 0	537.3	24.4	7.704	12.753 days	1.00	<i>E,K,P</i>
²³² Th(<i>n, f</i>) ⁹⁵ Zr	1.50 + 0	7.40 + 0	1.50 + 0	7.10 + 0	724.2	44.1	5.374	64.02 days	1.00	<i>E,L</i>
					756.7	54.4				
⁵⁴ Fe(<i>n, p</i>) ⁵⁴ Mn	2.30 + 0	7.70 + 0	2.30 + 0	7.40 + 0	834.838	99.9746		312.13 days	0.15	<i>E</i>
⁵⁸ Ni(<i>n, p</i>) ⁵⁸ Co	2.00 + 0	7.60 + 0	2.00 + 0	7.30 + 0	810.7	99.45		70.83 days	0.30	<i>E</i>
⁴⁷ Ti(<i>n, p</i>) ⁴⁷ Sc	1.90 + 0	7.60 + 0	1.90 + 0	7.30 + 0	159.4	68.3		3.35 days	0.15	<i>E,Q,R</i>
³² S(<i>n, p</i>) ³² P	2.40 + 0	7.50 + 0	2.30 + 0	7.30 + 0	1710.6	100. (beta)		14.284 days	...	<i>S</i>
⁶⁴ Zn(<i>n, p</i>) ⁶⁴ Cu	2.60 + 0	7.70 + 0	2.60 + 0	7.40 + 0	1345.7	0.4743		12.700 h	0.30	<i>E</i>
²⁷ Al(<i>n, p</i>) ²⁷ Mg	3.50 + 0	9.40 + 0	3.40 + 0	9.20 + 0	843.8	71.8		9.46 min	0.30	<i>E</i>
					1014.4	28.0				
⁴⁶ Ti(<i>n, p</i>) ⁴⁶ Sc	3.80 + 0	9.60 + 0	3.70 + 0	9.20 + 0	889.3	99.983		83.788 days	0.15	<i>E,Q</i>
					1120.5	99.986				
⁵⁶ Fe(<i>n, p</i>) ⁵⁶ Mn	5.50 + 0	1.14 + 1	5.50 + 0	1.10 + 1	846.7	98.85		2.57878 h	0.15	<i>E,T</i>
					1810.7	26.9				
²⁴ Mg(<i>n, p</i>) ²⁴ Na	6.50 + 0	1.17 + 1	6.50 + 0	1.13 + 1	1368.6	99.993		14.9574 h	0.03	<i>E,J</i>
					2754.1	99.872				
²⁷ Al(<i>n, α</i>) ²⁴ Na	6.50 + 0	1.21 + 1	6.50 + 0	1.17 + 1	1368.6	99.993		14.9574 h	0.30	<i>E,J</i>
					2754.1	99.872				
⁴⁸ Ti(<i>n, p</i>) ⁴⁸ Sc	5.90 + 0	1.24 + 1	5.90 + 0	1.20 + 1	983.5	100.1		43.7 h	0.15	<i>E</i>
					1037.5	97.56				
					1312.1	100.1				
⁹³ Nb(<i>n, 2n</i>) ^{92m} Nb	9.70 + 0	1.45 + 1	9.40 + 0	1.40 + 1	934.4	99.1		10.15 days		
¹²⁷ I(<i>n, 2n</i>) ¹²⁶ I	9.70 + 0	1.47 + 1	9.70 + 0	1.43 + 1	388.6	35.6		12.93 days	0.25	<i>E</i>
					666.3	32.9				
⁶⁵ Cu(<i>n, 2n</i>) ⁶⁴ Cu	1.08 + 1	1.57 + 1	1.07 + 1	1.53 + 1	1345.7	0.475		12.701 h	0.15	<i>E,M</i>
⁶³ Cu(<i>n, 2n</i>) ⁶² Cu	1.19 + 1	1.66 + 1	1.19 + 1	1.63 + 1	875.7	0.150		9.74 min	0.15	<i>E,H</i>
⁹⁰ Zr(<i>n, 2n</i>) ⁸⁹ Zr	1.28 + 1	1.69 + 1	1.27 + 1	1.67 + 1	909.1	99.0		78.4 h	0.10	
⁵⁸ Ni(<i>n, 2n</i>) ⁵⁷ Ni	1.32 + 1	1.71 + 1	1.31 + 1	1.69 + 1	1377.6	81.2		35.9 h	0.30	

^A Energy limits inside of which 95 % of the detector response occurs for each reaction (see Practice E261 and Refs (7,8)). The foils are assumed to have Cd covers as described in Footnote E.

^B Data taken from Refs (9-11). Ref (11) takes precedent, but it only addresses reactions used in detector calibration. In other cases, Ref (9) provides the half-life and Ref (10) provides the gamma yields. Many gamma-ray energies rounded to nearest 0.1 keV. For uncertainties on values, see references.

^C Fission yields can be found in Ref (12).

^D Choice of mass is based on assumed foil diameter of 1.27 cm.

^E Cd covers 0.5 to 1-mm thicknesses. Pairs of bare and Cd-covered foils are advantageous for resonance reactions.

^F Use ⁵⁹Co instead of ¹⁹⁷Au and ⁵⁵Mn for very long irradiations.

^G Use dilute aluminum-gold alloy (<0.2 % Au) when possible.

^H Do not count the 0.511 line.

^I Use in the form of NaCl.

^J The 1986 edition of Ref (13) has a typographical error for the half-life of ²⁴Na. The correct number can be found in previous editions. The correct number can also be found in Ref (9).

^K This is the 40.27-h daughter of 12.75-day ¹⁴⁰Ba. Wait 5 days for maximum decay rate (see Test Method E393).

^L E_{γ} = 0.01 MeV shielded with ¹⁰B sphere. (Use of ¹⁰B shield is important for soft (TRIGA) spectra where $\Phi(E < 0.01$ MeV) will otherwise dominate).

^M Precautions must be taken in counting because of the low gamma-ray energy. See Test Method E1297 for details of ^{93m}Nb use. For ^{103m}Rh, X-rays are typically counted rather than listed gamma ray. See Ref (10).

^N If a ¹⁰B sphere is used for the ²³⁹Pu foil, then a ¹⁰B sphere should also be used for the ²³⁷Np foil so that correction for ²³⁹Pu impurity in the ²³⁷Np foil can be made.